

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Motor-Starter

Name and address of the applicant
Nom et adresse du demandeur

Benedict GmbH
1220 Wien, Liebigasse 7, Austria

Name and address of the manufacturer
Nom et adresse du fabricant

Benedict GmbH
1220 Wien, Liebigasse 7, Austria

Name and address of the factory
Nom et adresse de l'usine

Benedict GmbH
1220 Wien, Liebigasse 7, Austria

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

AC 690 V; 50-60 Hz; AC1 see page 1 of test reports
AC 400 V; 50-60 Hz; AC 3 see page 1 of test reports
AC 240 V; 50-60 Hz; AC15 see page 1 of test reports

Trademark (if any)
Marque de fabrique (si elle existe)

Ω, Benedikt & Jäger

Model / Type Ref.
Ref. de type

K1-09Dxx/-K2-09Axx/-12Axx/-16Axx/-23Axx/-30Axx + U12/16xxx
K85Axx/-110Axx + U85x

Additional information (if necessary)
Information complémentaire (si nécessaire)


A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-4-1(ed.2);am1


As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

2.03.00356.1.0-K109/B&J, -K209/B&J, -K212/B&J, -K216/B&J, -K223/B&J, -K230/B&J, -K85/B&J, -K110/B&J

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification





AUSTRIAN ELECTROTECHNICAL ASSOCIATION
A-1190 Wien, Kahlenberger Str. 2A



Dipl.-Ing. W. Martin



Date: 2004-02-25

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No.	: 2.03.00356.1.0-K109/B&J
Tested by (+ signature).....	: Ing.J.Ainetter 
Approved by (+ signature)	: Ing.K.Farthofer 
Date of issue	: 02.02.2004
Testing laboratory	: Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address.....	: A – 1031 Vienna, Faradaygasse 3
Testing location.....	: as above
Applicant.....	: Benedict GmbH (Ω Benedikt & Jäger)
Address.....	: A – 1220 Vienna, Lieblgasse 7
Standard	: EN 60 947-4-1:2000-11
Test Report Form No.	: 69474-1A
Master TRF	: reference No. 69474-1A, dated 95-07
Copyright blank test report.....	: the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure	: CB-scheme
Procedure deviation.....	: N.A.
Non-standard test method	: N.A.
Type of test object	: Motor-Starter
Trademark	: Ω, Benedikt & Jäger
Model/type reference	: K1-09Dxx + U12/16xxx
Manufacturer.....	: Ω Benedikt & Jäger
Rating	: AC1 20A 690V 50-60Hz AC3/AC4 9A 400V 50-60Hz AC15 3A 240V 50-60Hz

Copy of marking plate

Contactor K1-09D
IEC/EN60947-4-1
VDE0660

AC3 9A

400V~

AC1 = I_{th}
690V~ 20A



Made in Austria

AC2, AC3	220	380
V~	240	690
kW	3	4

LISTED IND. CONT. EQ. 93B2

600V ac 15amp.
Aux. Cont.
A600 Q600

v. max | 120 | 240 | 480 | 600

hp 3ph | 1.5 | 3 | 5 | 7.5

hp 1ph | 0.5 | 1.5 | - | -

14AWG - 18AWG WIRE

60/75°C Cu only

TIGHT TORQUE 9 lb.-in.

SUITABLE FOR USE ON

A CIRCUIT OF DELIVE-

RING 5000RMS SYM. AMP.

600 VOLTS AC MAXIMUM

MAX. FUSE SIZE 30 AMP.

Overload Relay

U12/16E 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A
≡ Typ 1* 25A **2.7-4A**
gI(gG) Typ 2* 10A | 96 | 98

500VA
max. 4A
D/R 440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 93B3
600V ac
≡ Max. fuse size **15A**
150V 95 | 97
300V 95 | 97
500Va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16A 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A
≡ Typ 1* 25A **2.7-4A**
gI(gG) Typ 2* 10A | 96 | 98

500VA
max. 4A
D/R 440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 93B3
600V ac
≡ Max. fuse size **15A**
150V 95 | 97
300V 95 | 97
500Va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16EM

IEC/EN60947-4-1 VDE0660
93B3
Auslöseklasse / Trip class: 10A
≡ Typ 1* 25A **2.7-4A**
gI(gG) Typ 2* 10A | 96 | 98

500VA
max. 4A
D/R 440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 93B3
600V ac
≡ Max. fuse size **15A**
150V 95 | 97
300V 95 | 97
500Va max. 4A

S. No. [redacted]

Bereich Range	300V 415V 500V		300V 415V 500V	
	115V	500V	115V	500V
0.17 - 0.18A	-	0.2 - 1.2A	-	1A
0.18 - 0.21A	-	1.2 - 1.6A	-	1A
0.21 - 0.24A	-	1.6 - 2.1A	2A	2A
0.24 - 0.26A	-	2.1 - 4A	2.5A	2.5A

U12/16EQ 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A
≡ Typ 1* 25A **2.7-4A**
gI(gG) Typ 2* 10A | 96 | 98

500VA
max. 4A
D/R 440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 93B3
600V ac
≡ Max. fuse size **15A**
150V 95 | 97
300V 95 | 97
500Va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16U 4


IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A
≡ Typ 1* 25A **2.7-4A**
gI(gG) Typ 2* 10A | 96 | 98

600V~
max. 4A
D/R 440V~ 95 | 97
690V~ 95 | 97


LISTED IND. CONT. EQ. 93B3
600V ac
≡ Max. fuse size **15A**
150V 95 | 97
300V 95 | 97
500Va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Photo:
K1-09D10



Overload Relay U12/16E



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 1 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 20
- conventional enclosed thermal current I_{the} (A) : 20
- rated operational current I_e (A) : 20
- rated uninterrupted I_u (A) : 20
- utilization category..... : AC1, AC3, AC4

Short-circuit characteristic..... :

- rated prospective short-circuit current "r" (kA) : 1
- rated conditional short-circuit current I_q (kA) : 1

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : 1
- number and kind of contact elements : 1 NO or 1 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse

Possible test case verdicts:

- test case does not apply to the test object..... : N(.A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HK' or 'HKM'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:

Contactor

K1-09D x x

I I >>> : 0, 1 : Number of NC auxiliary contacts

I >>>> : 0, 1 : Number of NO auxiliary contacts

Overload Relay

U12/16 x x x

I I I >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /

I I 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /

I I 2,7 – 4 / 4 – 6 / 6 – 9 A

I I

I I >>>> : M ... With additional quick trip up to 4A (optional)

I : Q ... Thermic quick trip up to 14A (optional)

I

I >>>> : U ... Change over auxiliary contacts

: A ... Change over auxiliary contacts with autom. Reset

: E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz

6 – 600V 60Hz

12 – 250V DC

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 20A, 690V AC3 AC4 9A, 400V Contactor AC15 3A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	1 kA Type '1' 25A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 3A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C	Cover (grey)	P
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	—
	- nominal voltage of supply system	400 / 690V	—
	- overvoltage category	IV	—
	- pollution degree	3	—
	- field-in or homogeneous	Inhomogeneous	—
	- minimum clearances (mm)	8	—
	- measured clearances (mm)	≥10	—
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		—
	- Ie		—
	- minimum clearances L-L/L-A (mm)		—
	- measured clearances L-L/L-A (mm)		—
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	—
	diameter of thread (mm)	M4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	—
	number of conductor of the smallest cross section	1	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	1,4	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	80	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5 6 // 1,5 flex	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 // 6,4 9,5 // 6,4	—
	height between the equipment and the platen (mm)	279 // 260 279 // 260	—
	mass at the conductor(s) (kg)	0,7 // 0,3 1,4 // 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	50 // 30 80 // 30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,75 0,5	—
	maximum cross-sectional area of conductor (mm ²)	6 4	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	2,5	—
	diameter of thread (mm)	M 3,5	—
	torque (Nm)	0,8	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	0,5	—
	number of conductor of the smallest cross section	2	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	2,5	—
	number of conductor of the largest cross-sectional	2	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	0,7	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			
	force (N)	50		—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Flexion test			
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5	0,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1	1	—
	diameter of bushing hole (mm)	9,5	6,4	—
	height between the equipment and the platen (mm)	279	260	—
	mass at the conductor(s) (kg)	0,7	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			
	force (N)	50	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
8.1.7.2	Connecting capacity			P
	type of conductors	Rigid	Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,5	0,5	—
	maximum cross-sectional area of conductor (mm ²)	2,5	2,5	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2	2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals - Main circuit: - Auxiliary circuit	2T1, 4T2, 6T3 95-96, 97-98, 13-14, 21-22, A1, A2	P
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection: IP		N
	Test for first characteristic		N
	Test for first numeral: 1: 2: 3: 4: 5: 6:		—
	Test for second characteristic		N
	Test for second numeral: 1: 2: 3: 4: 5: 6: 7: 8:		—

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise		P
	ambient temperature 10-40 °C: 25		—
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure		—
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		—
	- conventional enclosed thermal current I _{the} (A) ..		—
	- cable/busbar cross-section (mm ²) / (mm)		—
	- temperature rise of main circuit terminals (K)	<	—
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	10	—
	- cable cross-section (mm ²)	1,5	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	—
	Coils and electromagnets, test conditions:	AC	DC
	- rated control supply voltage U _s (V)	240	24
	- Class of insulating material	F	F
	- temperature rise of coil and electromagnets (K) :	≤ 68	≤ 58
	Starter	Tested with setting range 6 – 9 A	
	test enclosure W x H x D (mm x mm x mm)	None	—
	material of enclosure	-	—
	Main circuits, test conditions: *Tested with 9A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	9 (20*)	—
	- cable/busbar cross-section (mm ²) / (mm)	1,5 mm ²	—
	- temperature rise of main circuit terminals (K)	≤ 62	—
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	—
	- cable cross-section (mm ²)	1	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 44	—
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC	DC
	rated control supply voltage U _s (V)	240	24
	frequency (Hz)	50	DC

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	80	74	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	36	27	P
9.3.3.2.2	Relays and releases	Setting Range 6 – 9 A		P
	Conditions for thermal and time-delay magnetic overload relays only:			p
	type of time-delay overload relay	Thermal, Temp. compensated		
	trip class	10A		
	current setting I _{set} :	6 A	9 A	
	ambient temperature (°C)	24		
	test enclosure W x H x D (mm x mm x mm)	None		
	cable/busbar cross-section (mm ²) / (mm)	1,5		
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	6,3 A	9,45 A	
		No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	7,2 A	10,8 A	
		1:20	3:40	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	9 A	13,5 A	
		0:21	0:17	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T _p (s)	43,2 A	64,8 A	
		5,2	4,6	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	Ambient temperature: - 5 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	6,3 A No tripping	9,45 A No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	7,2 A 0:35	10,8 A 2:40	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	9 A 1:10	13,5 A 0:40	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7.2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	43,2 A 5,6	64,8A 4,7	—
	Ambient temperature: + 40 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	6,3 A No tripping	9,45 A No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	7,2 A 1:10	10,8 A 4:55	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	9 A 0:11	13,5 A 0:27	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N	—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	43,2 A 64,8 A 5 4,8	—
	Limits of operation of three-pole thermal overload relays energized on two poles:		P
	ambient temperature (°C)	24	—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	6 A / 5,4 A 9 A / 8,1 A No tripping No tripping	—
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h	6,9 A / 0 A 10,35 A / 0 A 1:25 0:40	—
9.3.3.2.2	Relays and releases	Setting Range 1,8 – 2,7 A *** Q ***	P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. compensated	—
	trip class	10A	—
	current setting I_{set} :	1,8A 2,7 A	—
	ambient temperature (°C)	24	—
	test enclosure W x H x D (mm x mm x mm)	None	—
	cable/busbar cross-section (mm ²) / (mm)	1,0	—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	1,89 A 2,84 A No tripping No tripping	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	2,16 A 1:45	3,24 A 3:25	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	2,7 A 0:17	4,05 A 0:28	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T_p (s)	12,96 A 3,2	19,44 A 3,0	—
	Ambient temperature: - 5 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	1,89 A No tripping	2,84 A No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	2,16 A 5:20	3,24 A 4:55	—
	for class 10A overlod relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	2,7 A 0:25	4,05 A 0:52	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	12,96 A	19,44A	—
: 3,3		3,1	
	Ambient temperature: + 40 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	1,89 A	2,84 A	—
: No tripping		No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	2,16 A	3,24 A	—
 min:sec : 0:30		0:45	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current	2,7 A	4,05 A	—
 min:sec : 0:07		0:22	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	12,96 A	19,44 A	—
: 3,1		2,9	
	Limits of operation of three-pole thermal overload relays energized on two poles:			P
	ambient temperature (°C)	23		—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	1,8 A / 1,62 A	2,7 A / 2,43 A	—
: No tripping		No tripping	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h..... min:sec :	2,07 A / 0 A 3,11 A / 0 A 2:45 1:05	—
9.3.3.4	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	—
	- test Uimp main circuits (kV)	9,8 / 7	P
	- test Uimp auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	—
	rated operational voltage Ue (V)	690	—
	rated operational current Ie (A) or power (kW)	20A	—
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 730 L2: 729 L3: 729	—
	- test current I/Ie = 1,5 (A)	L1: 38 L2: 38 L3: 38,5	—
	- power factor/time constant	L1: 0,78 L2: 0,78 L3: 0,79	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- on-time (ms)	160	—
	- off-time (s)	9,8	—
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	—
	rated operational voltage U_e (V)	400V	—
	rated operational current I_e (A) or power (kW)	9A	—
	Conditions, make operations AC3/AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 420 L2: 421 L3: 421	—
	- test current $I/I_e =$ (A)	L1: 108 L2: 110 L3: 108	—
	- power factor/time constant	L1: 0,45 L2: 0,45 L3: 0,45	—
	- on-time (ms)	100	—
	- off-time (s)	10	—
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Measured oscillatory frequency (kHz)	L1: 39 L2: 38 L3: 38	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	—
	rated operational voltage Ue (V)	400	—
	rated operational current Ie (A) or power (kW)	9A	—
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 420 L2: 420 L3: 420	—
	- test current I/Ie = (A)	L1: 54,5 L2: 55 L3: 55	—
	- power factor/time constant	L1: 0,47 L2: 0,47 L3: 0,47	—
	- on-time (ms)	100	—
	- off-time (s)	4	—
	- number of make/break operations	6000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 34 L2: 33,5 L3: 34	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	
	rated operational voltage (V)	690	
	rated operational current I _e (A) or power (kW)	20A	
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 730 L2: 728 L3: 730	
	test current (A)	L1: 38 L2: 38 L3: 38,5	
	power factor/time constant	L1: 0,78 L2: 0,78 L3: 0,79	
	- on-time (ms)	160	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- off-time (s)	2,3	—
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	—

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r": U12/16 0,4 -0,6A Represents setting ranges up to 9A		
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD, co-ordination type 1	25A / 500V	—
	ratings of SCPD, co-ordination type 2	-	—
	rated operational current Ie (A) AC-3	9A	—
	prospective current "r" (kA)	1	—
	test voltage (V)	L1: 424 L2: 424 L3: 425	—
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	—
	power factor	0,95	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dta (A ² s) / peak current I (A)	L1: 1750 A ² s / 807A L2: 2180 A ² s / 887 A L3: 1860 A ² s / 903 A	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dta (A ² s) / peak current I (A)	L1: 108 A ² s / 270 A L2: 695 A ² s / 586 A L3: 884 A ² s / 601 A	—
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		—
	ratings of SCPD, co-ordination type 1		—
	ratings of SCPD, co-ordination type 2		—
	rated operational current Ie (A) AC-3		—
	prospective current "Iq" (kA)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	test voltage (V)	L1: L2: L3:	
	r.m.s. test current (A)	L1: L2: L3:	
	peak current (A)	L1: L2: L3:	
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2t (A ² s)	L1: L2: L3:	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 U _e) for 1 min (V)		
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	
	rated operational current Ie (A) max. AC-3	9	
	test current (Ie) (A)	72	
	duration of test: 10 s	10s	
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements				P
temperature rise dT of part:	No.	dT (K)	Required dT (K)	
Main Terminals Contactor (9A)	1	35	65	
	3	42	65	
	5	38	65	
Main Terminal Overload Relay (9A)	2	60	65	
	4	61	65	
	6	62	65	
Auxilixary Terminals Contactor (10A)	13	40	65	
	14	40	65	
Auxiliary Terminal Overload Relay (4A)	95	44	65	
	96	40	65	
Coil:	240V	50Hz	68	135
	24V	DC	58	135



EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	—
	rated operational voltage U_e (V)	240	—
	rated operational current I_e (A) or power (kW)	3	—
	Conditions, make/break operations:		
	- test voltage $U/U_e = 1,1$ (V)	L1: 266 L2: - L3: -	—
	- power factor/time constant	L1: 0,29 L2: - L3: -	—
	- make operations: test current I/I_e (A)	L1: 61 L2: - L3: -	—
	- break operations: test current I/I_e (A)	L1: 61 L2: - L3: -	—
	- on-time (ms)	300	—
	- operating cycles per minute	6	—
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	—
	rated operational voltage Ue (V)	240	—
	rated operational current Ie (A) or power (kW)	3	—
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	—
	- power factor/time constant	L1: 0,29 L2: - L3: -	—
	- make operations: test current I/Ie (A)	L1: 61 L2: - L3: -	—
	- break operations: test current I/Ie (A)	L1: 6,5 L2: - L3:	—
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	—
	- operating cycles per minute	15	—
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		—
	rated operational voltage Ue (V)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD	20A / 500V	—
	prospective current (kA)	1	—
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	—
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	—
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1010 A ² s / 760A L2: 1010 A ² s / 760 A L3: 950 A ² s / 880 A	—
	time interval between test (min. 3 min)		—
	second making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1090 A ² s / 710 A L2: 910 A ² s / 850 A L3: 780 A ² s / 710 A	—
	time interval between test (min. 3 min)		—
	third making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 870 A ² s / 780 A L2: 170 A ² s / 465 A L3: 880 A ² s / 790 A	—
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No.:	2.03.00356.1.0-K209/B&J
Tested by (+ signature).....:	Ing.J.Ainetter 
Approved by (+ signature)	Ing.K.Farthofer 
Date of issue.....:	02.02.2004
Testing laboratory	Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address.....:	A – 1031 Vienna, Faradaygasse 3
Testing location.....:	as above
Applicant.....:	Benedict GmbH (Ω Benedikt & Jäger)
Address.....:	A – 1220 Vienna, Liebiggasse 7
Standard	EN 60 947-4-1:2000-11
Test Report Form No.:	69474-1A
Master TRF.....:	reference No. 69474-1A, dated 95-07
Copyright blank test report.....:	the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure	CB-scheme
Procedure deviation.....:	N.A.
Non-standard test method	N.A.
Type of test object	Motor-Starter
Trademark	Ω, Benedikt & Jäger
Model/type reference	Kx2-09Axx + U12/16xxx
Manufacturer.....:	Ω Benedikt & Jäger
Rating	AC1 20A 690V 50-60Hz AC3/AC4 10A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contacteur K2-09A

K2-09A

IEC / EN60947-4-1	AC1=I _{th}			
VDE0660	AS3947-4-1	600V~ 25A		
AC2, ACS	220	380	415	660
V~	240	400	440	500
500	660			
KW	3	4	4,5	5,5



MADE IN AUSTRIA

LISTED IND. CONT.

EQUIP. 93B2	
600V ac 25amp A600	
max. v	120 200 240 480 600
3ph hp	1.5 2 3 5 7.5
1ph 2p hp	0.5 1 1.5 - -

SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NOT MORE THAN 5000 RMS SYMMETRICAL AMPS 600 VOLTS MAX. WHEN PROTECTED BY A FUSE RATED 30AMP.

TIGHTENING TORQUE 8.1 lb. in.

14AWG-100MG

WIRE 60°C Cu ONLY

Overload Relay

U12/16E 4

IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1 25A **2,7-4A**
dL(gG) Typ 2 10A

600VA max. 4A
O/R
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms, sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16A 4

IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1 25A **2,7-4A**
dL(gG) Typ 2 10A

600VA max. 4A
O/R
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms, sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16EM

IEC / EN60947-4-1 VDE0660
Ausstoßklasse / Trip class: 10A

BENEDIKT & JÄGER

U12/16EM

S. No. [redacted]

Strom	250V	400V	500V	600V
1,5	1,5	1,5	1,5	1,5
2	2	2	2	2
3	3	3	3	3
5	5	5	5	5
7,5	7,5	7,5	7,5	7,5

Made in Austria

U12/16EQ 4

IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1 25A **2,7-4A**
dL(gG) Typ 2 10A

600VA max. 4A
O/R
440V~ 95
690V~ 95

Made in Austria

U12/16U 4

IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1 25A **2,7-4A**
dL(gG) Typ 2 10A

600VA max. 4A
O/R
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms, sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.




Made in Austria

Photo:

K2-09A10 AC-operated


K2-09A10= DC-operated

KG2-09A10



Overload Relay:

U12/16E



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 1 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 20
- conventional enclosed thermal current I_{the} (A) : 20
- rated operational current I_e (A) : 20
- rated uninterrupted I_u (A) : 20
- utilization category..... : AC1, AC3, AC4

Short-circuit characteristic..... :

- rated prospective short-circuit current " r " (kA) : 1
- rated conditional short-circuit current I_q (kA) : 1

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : 1
- number and kind of contact elements : 1 NO or 1 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse: 25A up to 11A AC3/AC4
63A from 10A AC3/AC4

Possible test case verdicts:

- test case does not apply to the test object..... : N(A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HN' or 'HA'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:**Contactor****Kx2-09A x x**

| | | >>> : 0, 1 : Number of NC auxiliary contacts
 | | >>>> : 0, 1 : Number of NO auxiliary contacts
 | >>>> : G : DC coil supply (optional)

Overload Relay**U12/16 x x x**

| | | >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /
 | | 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /
 | | 2,7 – 4 / 4 – 6 / 6 – 9 / 8 – 11 / 10 – 14 A
 | |
 | | >>>> : M ... With additional quick trip up to 4A (optional)
 | : Q ... Thermic quick trip up to 14A (optional)
 |
 | >>>> : U ... Change over auxiliary contacts
 : A ... Change over auxiliary contacts with autom. Reset
 : E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz
 6 – 600V 60Hz
 12 – 250V DC *

12V up to 24V: Double Winding Coil with Late Break Contact in series to coil.

25V up to 250V: Dropping Resistor with Late Break Contact in series to coil.

KG – type: Without Late Break Contact

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 20A, 690V AC3 AC4 10A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	1 kA Type '1' 63A/25A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C	Cover (grey)	P
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- le		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	
	diameter of thread (mm)	M4	
	torque (Nm)	1,2	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	
	number of conductor of the smallest cross section	1	
	diameter of bushing hole (mm)	6,4	
	height between the equipment and the platen (mm)	260	
	mass at the conductor(s) (kg)	0,3	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	
	number of conductor of the largest cross-sectional	1	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	1,4	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			P
	force (N)	80		
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Flexion test	Overload		P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5	6 // 1,5	
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1	1 // 1	
	diameter of bushing hole (mm)	9,5 // 6,4	9,5 // 6,4	
	height between the equipment and the platen (mm)	279 // 260	279 // 260	
	mass at the conductor(s) (kg)	0,7 // 0,3	1,4 // 0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			P
	force (N)	50 // 30	80 // 30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
8.1.7.2	Connecting capacity			P
	type of conductors	Rigid	Flexible	
	minimum cross-sectional area of conductor (mm ²)	0,75	0,5	
	maximum cross-sectional area of conductor (mm ²)	6	4	
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2	2	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	4	
	diameter of thread (mm)	M 3,5	
	torque (Nm)	0,8	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	0,75	
	number of conductor of the smallest cross section	2	
	diameter of bushing hole (mm)	6,4	
	height between the equipment and the platen (mm)	260	
	mass at the conductor(s) (kg)	0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	4	
	number of conductor of the largest cross-sectional	2	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	0,9	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	4 // 2,5 1,5 // 0,5	
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	
	diameter of bushing hole (mm)	9,5 6,4	
	height between the equipment and the platen (mm)	279 260	
	mass at the conductor(s) (kg)	0,9 // 0,7 0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60 // 50 40 // 30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	
	minimum cross-sectional area of conductor (mm ²)	0,75 0,75	
	maximum cross-sectional area of conductor (mm ²)	4 2,5	
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals		P
	- Main circuit::	2T1, 4T2, 6T3	
	- Auxiliary circuit	95-96, 97-98, 13-14, 21-22, A1, A2	
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC and DC - KG	P
	ambient temperature 10-40 °C	25	
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		
	material of enclosure		
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		
	- conventional enclosed thermal current I _{the} (A) ..		
	- cable/busbar cross-section (mm ²) / (mm)		
	- temperature rise of main circuit terminals (K)	<	
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
	Coils and electromagnets, test conditions:	AC DC Type KG	P
	- rated control supply voltage U _s (V)	240 220	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 76 ≤ 66	
	Starter	Tested with setting range 10 – 14 A	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	material of enclosure	Metal	
	Main circuits, test conditions: *Tested with 14A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	14 (20*)	
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²	
	- temperature rise of main circuit terminals (K)	≤ 62	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 44	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC Type KG	P
	rated control supply voltage U _s (V)	240 220	
	frequency (Hz)	50 DC	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s	80 81	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	47 23	P
9.3.3.3	Temperature rise	Type DC	P
	ambient temperature 10-40 °C	25	
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		
	material of enclosure		
	Main circuits, test conditions:		N
	- conventional thermal current I_{th} (A)		
	- conventional enclosed thermal current I_{the} (A) ..		
	- cable/busbar cross-section (mm ²) / (mm)		
	- temperature rise of main circuit terminals (K)	<	
	Auxiliary circuit, test conditions:		P
	- rated operation current I_e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
	Coils and electromagnets, test conditions:	DC	P
	- rated control supply voltage U_s (V)	220 24	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 40 ≤ 64	
	Starter	Tested with setting range 10 – 14 A	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	material of enclosure	Metal	
	Main circuits, test conditions: *Tested with 14A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I_{th} (A)	14 (20*)	
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- temperature rise of main circuit terminals (K)	≤ 62	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I_e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	DC	P
	rated control supply voltage U_s (V)	220 24	
	frequency (Hz)	DC DC	
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s	69 70	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	31 38	P
9.3.3.2.2	Relays and releases Setting Range 10 – 14 A		P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. compensated	
	trip class	10A	
	current setting	I_{set} : 10 A 14 A	
	ambient temperature (°C)	25	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	cable/busbar cross-section (mm ²) / (mm)	2,5	
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A 14,7 A No tripping No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	12 A 16,8 A 3:55 0:43	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A 21 A 0:22 0:08	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N	
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T_p (s)	72 A 100,8 A 2,1 2,5	
	Ambient temperature: - 5 °C		
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A 14,7 A No tripping No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	12 A 16,8 A 22:10 1:45	
	for class 10A overlod relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A 21 A 0:36 0:12	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	72 A	100,8A	
	Ambient temperature: + 40 °C	2,1	2,0	
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A	14,7 A	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	12 A	16,8 A	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A	21 A	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	0:50	0:12	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	0:08	0:05	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	72 A	100,8 A	
	Limits of operation of three-pole thermal overload relays energized on two poles:	2	2,2	P
	ambient temperature (°C)	25		
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	10 A / 9 A	14 A / 12,6 A	
		No tripping	No tripping	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h min:sec :	11,5 A / 0 A 16,1 A / 0 A 1:00 0:24	
9.3.3.4	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	
	- test Uimp main circuits (kV)	9,8 / 7	P
	- test Uimp auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	
	rated operational voltage Ue (V)	690	
	rated operational current Ie (A) or power (kW)	20A	
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 725 L2: 730 L3: 730	
	- test current I/Ie = 1,5 (A)	L1: 38 L2: 38 L3: 38	
	- power factor/time constant	L1: 0,78 L2: 0,78 L3: 0,79	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- on-time (ms)	160	
	- off-time (s)	9,8	
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	
	rated operational voltage U_e (V)	400V	
	rated operational current I_e (A) or power (kW)	10A	
	Conditions, make operations AC3/AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 426 L2: 425 L3: 427	
	- test current $I/I_e =$ (A)	L1: 192 L2: 193 L3: 192	
	- power factor/time constant	L1: 0,4 L2: 0,4 L3: 0,41	
	- on-time (ms)	100	
	- off-time (s)	10	
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Measured oscillatory frequency (kHz)	L1: 47 L2: 48 L3: 48	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	
	rated operational voltage U_e (V)	400	
	rated operational current I_e (A) or power (kW)	10A	
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 427 L2: 425 L3: 428	
	- test current $I/I_e =$ (A)	L1: 60 L2: 60 L3: 60	
	- power factor/time constant	L1: 0,45 L2: 0,45 L3: 0,45	
	- on-time (ms)	100	
	- off-time (s)	4	
	- number of make/break operations	6000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 37,5 L2: 38 L3: 38	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	
	rated operational voltage (V)	690	
	rated operational current I _e (A) or power (kW)	20A	
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 725 L2: 730 L3: 730	
	test current (A)	L1: 38 L2: 38 L3: 38	
	power factor/time constant	L1: 0,78 L2: 0,79 L3: 0,79	
	- on-time (ms)	160	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- off-time (s)	2,3	
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	

9.3.4	TEST SEQUENCE III	
	Performance under short-circuit conditions	
9.3.4.2.1	Test at de prospective current "r": U12/16 0,4 -0,6A Represents setting ranges up to 11A	
	type of SCPD	Siemens Diazed gL / gG
	ratings of SCPD, co-ordination type 1	25A / 500V
	ratings of SCPD, co-ordination type 2	-
	rated operational current Ie (A) AC-3	10A
	prospective current "r" (kA)	1
	test voltage (V)	L1: 424 L2: 423 L3: 425
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	
	power factor	0,95	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dta (A ² s) / peak current I (A)	L1: 1750 A ² s / 807A L2: 2180 A ² s / 887 A L3: 1860 A ² s / 903 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dta (A ² s) / peak current I (A)	L1: 108 A ² s / 270 A L2: 695 A ² s / 586 A L3: 884 A ² s / 601 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
9.3.4.2.1	Test at de prospective current "r": U12/16 13 -18A Represents setting ranges higher 10A		
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD, co-ordination type 1	63A / 500V	
	ratings of SCPD, co-ordination type 2	-	
	rated operational current Ie (A) AC-3	10A	
	prospective current "r" (kA)	1	
	test voltage (V)	L1: 424 L2: 423 L3: 425	
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	
	power factor	0,95	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dta (A ² s) /peak current I (A)	L1: 20,8 kA ² s / 1330 A L2: 19,6 kA ² s / 1283 A L3: 23 kA ² s / 1210 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dta (A ² s) /peak current I (A)	L1: 22,1 kA ² s / 1260 A L2: 19,5 kA ² s / 1283 A L3: 21,4 kA ² s / 1306 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		
	ratings of SCPD, co-ordination type 1		
	ratings of SCPD, co-ordination type 2		
	rated operational current Ie (A) AC-3		
	prospective current "Iq" (kA)		
	test voltage (V)	L1: L2: L3:	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	r.m.s. test current (A)	L1: L2: L3:	
	peak current (A)	L1: L2: L3:	
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² t _{ta} (A ² s)	L1: L2: L3:	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	
	rated operational current Ie (A) max. AC-3	10	
	test current (Ie) (A)	80	
	duration of test: 10 s	10s	
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements				P
Main Terminals Contactor (14A)				
		1	51	65
		3	57	65
		5	57	65
Main Terminal Overload Relay (14A)				
		2	53	65
		4	62	65
		6	57	65
Auxiliary Terminals Contactor (16A)				
		13	43	65
		14	42	65
Auxiliary Terminal Overload Relay (4A)				
		95	44	65
		96	40	65
Coil:				
	240V	50Hz	76	135
	24V + 10%	DC	64	135
	220V + 10%	DC	40	135
Type: KG	220V	DC	66	135

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	
	rated operational voltage U_e (V)	240	
	rated operational current I_e (A) or power (kW)	12	
	Conditions, make/break operations:		
	- test voltage $U/U_e = 1,1$ (V)	L1: 266 L2: - L3: -	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/I_e (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/I_e (A)	L1: 123 L2: - L3: -	
	- on-time (ms)	300	
	- operating cycles per minute	6	
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	
	- operating cycles per minute	15	
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		
	rated operational voltage Ue (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD	25A / 500V	
	prospective current (kA)	1	
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	
	time interval between test (min. 3 min)		
	second making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	
	time interval between test (min. 3 min)		
	third making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No.	: 2.03.00356.1.0-K212/B&J
Tested by (+ signature)	: Ing.J.Ainetter 
Approved by (+ signature)	: Ing.K.Farthofer 
Date of issue	: 02.02.2004
Testing laboratory	: Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address	: A – 1031 Vienna, Faradaygasse 3
Testing location	: as above
Applicant	: Benedict GmbH (Ω Benedikt & Jäger)
Address	: A – 1220 Vienna, Lieblgasse 7
Standard	: EN 60 947-4-1:2000-11
Test Report Form No.	: 69474-1A
Master TRF	: reference No. 69474-1A, dated 95-07
Copyright blank test report	: the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure	: CB-scheme
Procedure deviation	: N.A.
Non-standard test method	: N.A.
Type of test object	: Motor-Starter
Trademark	: Ω, Benedikt & Jäger
Model/type reference	: Kx2-12Axx + U12/16xxx
Manufacturer	: Ω Benedikt & Jäger
Rating	: AC1 25A 690V 50-60Hz AC3/AC4 12A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contacteur K2-12A

K2-12A

IEC / EN60947-4-1	ACT = I _n			
VDE0660	ASS3947-4-1	690V~ 25A		
AC2, AC3	220	380	415	660
Y~	240	400	440	500
kW	4	5,5	6	7,5



MADE IN AUSTRIA

LISTED IND. CONT.
EQUIP. 93B3

690V ac 25amp A600 max. v	120	200	240	480	600
	3ph hp	2	3	3	7.5
1ph 2p hp	.75	2	2	-	-

SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NOT MORE THAN 6000 RMS SYMMETRICAL AMPS 600 VOLTS MAX. WHEN PROTECTED BY A FUSE RATED 40AMP.
TIGHTENING TORQUE 8.1 lb.-in.
14MMG-100MMG
WIRE 60°C CU ONLY

Overload Relay

U12/16E 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A
Typ "1" 25A **2,7-4A**
dL(gG) Typ "2" 10A

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

600VA max. 4A
0/R 440V~ 95T 690V~ 95

Made in Austria

U12/16A 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A
Typ "1" 25A **2,7-4A**
dL(gG) Typ "2" 10A

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

600VA max. 4A
0/R 440V~ 95T 690V~ 95

Made in Austria

U12/16EM

BENEDIKT & JÄGER
IEC / EN60947-4-1 VDE0660
Auslösekategorie / Trip class: 10A

U12/16EM

S. No. [redacted]

Breaker Range	215V	230V	Breaker Range	215V	230V
0.75 - 1.5A	-	-	0.75 - 1.5A	100	100
1.5 - 2.5A	-	-	1.5 - 2.5A	150	150
2.5 - 4A	-	-	2.5 - 4A	200	200
4 - 6A	-	-	4 - 6A	250	250

Made in Austria

U12/16EQ 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A
Typ "1" 25A **2,7-4A**
dL(gG) Typ "2" 10A

600VA max. 4A
0/R 440V~ 95T 690V~ 95

Made in Austria

U12/16U 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A
Typ "1" 25A **2,7-4A**
dL(gG) Typ "2" 10A

LISTED IND. CONT. EQ. 93B3
600V ac
Max. fuse size **15A**

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

600VA max. 4A
0/R 440V~ 95T 690V~ 95


Made in Austria

Photo:

K2-12A10 AC-operated



K2-12A10= DC-operated




KG2-12A10



Overload Relay:

U12/16E



Test item particulars:	
- method of operation	: Magnetic
- switching positions	: ON-OFF
- number of poles.....	Contactor: 3 Main 1 Aux
- kind of current.....	: AC
- number of phases.....	: 3
- rated frequency (Hz).....	: 50-60
- number of positions of main contacts.....	: 2
Rated and limiting values, main circuit..... :	
- rated operational voltage U_e (V)	: 690
- rated insulation voltage U_i (V)	: 690
- rated impulse withstand voltage U_{imp} (kV).....	: 8
- conventional free air thermal current I_{th} (A).....	: 25
- conventional enclosed thermal current I_{the} (A)	: 25
- rated operational current I_e (A)	: 25
- rated uninterrupted I_u (A)	: 25
- utilization category.....	: AC1, AC3, AC4
Short-circuit characteristic	
- rated prospective short-circuit current " I_r " (kA)	: 1
- rated conditional short-circuit current I_q (kA)	: 1
Rated and limiting values, auxiliary circuits..... : For Contactor	
- rated operational voltage (V).....	: 240
- rated frequency (Hz).....	: 50-60
- number of circuits	: 1
- number and kind of contact elements	: 1 NO or 1 NC
Co-ordination of short-circuit protective devices	
- kind of protective device.....	: Fuse: 25A up to 11A AC3/AC4 63A higher than 10A AC3/AC4
Possible test case verdicts:	
- test case does not apply to the test object.....	: N(.A.)
- test object does meet the requirement.....	: P(ass)
- test object does not meet the requirement.....	: F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HN' or 'HA'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:**Contactor****Kx2-12A x x**

| | | >>> : 0, 1 : Number of NC auxiliary contacts
 | | >>>> : 0, 1 : Number of NO auxiliary contacts
 | >>>> : G : DC coil supply (optional)

Overload Relay**U12/16 x x x**

| | | >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /
 | | 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /
 | | 2,7 – 4 / 4 – 6 / 6 – 9 / 8 – 11 / 10 – 14 A
 | |
 | | >>>> : M ... With additional quick trip up to 4A (optional)
 | : Q ... Thermic quick trip up to 14A (optional)
 |
 | >>>> : U ... Change over auxiliary contacts
 : A ... Change over auxiliary contacts with autom. Reset
 : E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz
 6 – 600V 60Hz
 12 – 250V DC *

12V up to 24V: Double Winding Coil with Late Break Contact in series to coil.

25V up to 250V: Dropping Resistor with Late Break Contact in series to coil.

KG – type: Without Late Break Contact

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 25A, 690V AC3 AC4 12A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	1 kA Type '1' 63A/25A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
Auxiliary circuits: Contactor			
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
Overload relays and releases:			
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C	Cover (blue)	P
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- le		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	
	diameter of thread (mm)	M4	
	torque (Nm)	1,2	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	
	number of conductor of the smallest cross section	1	
	diameter of bushing hole (mm)	6,4	
	height between the equipment and the platen (mm)	260	
	mass at the conductor(s) (kg)	0,3	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	
	number of conductor of the largest cross-sectional	1	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	1,4	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	80	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Overload	P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5 6 // 1,5	
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	
	diameter of bushing hole (mm)	9,5 // 6,4 9,5 // 6,4	
	height between the equipment and the platen (mm)	279 // 260 279 // 260	
	mass at the conductor(s) (kg)	0,7 // 0,3 1,4 // 0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	50 // 30 80 // 30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	
	minimum cross-sectional area of conductor (mm ²)	0,75 0,5	
	maximum cross-sectional area of conductor (mm ²)	6 4	
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	4	
	diameter of thread (mm)	M 3,5	
	torque (Nm)	0,8	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	0,75	
	number of conductor of the smallest cross section	2	
	diameter of bushing hole (mm)	6,4	
	height between the equipment and the platen (mm)	260	
	mass at the conductor(s) (kg)	0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	4	
	number of conductor of the largest cross-sectional	2	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	0,9	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	4 // 2,5 1,5 // 0,5	
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	
	diameter of bushing hole (mm)	9,5 6,4	
	height between the equipment and the platen (mm)	279 260	
	mass at the conductor(s) (kg)	0,9 // 0,7 0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60 // 50 40 // 30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	
	minimum cross-sectional area of conductor (mm ²)	0,75 0,75	
	maximum cross-sectional area of conductor (mm ²)	4 2,5	
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals		P
	- Main circuit::	2T1, 4T2, 6T3	
	- Auxiliary circuit	95-96, 97-98, 13-14, 21-22, A1, A2	
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC and DC - KG	P
	ambient temperature 10-40 °C	25	
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		
	material of enclosure		
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		
	- conventional enclosed thermal current I _{the} (A) ..		
	- cable/busbar cross-section (mm ²) / (mm)		
	- temperature rise of main circuit terminals (K)	<	
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
	Coils and electromagnets, test conditions:	AC DC Type KG	P
	- rated control supply voltage U _s (V)	240 220	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 76 ≤ 66	
	Starter	Tested with setting range 10 – 14 A	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	material of enclosure	Metal	
	Main circuits, test conditions: *Tested with 14A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	14 (25*)	
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²	
	- temperature rise of main circuit terminals (K)	≤ 62	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC Type KG	P
	rated control supply voltage U _s (V)	240 220	
	frequency (Hz)	50 DC	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	80 81	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	47 23	P
9.3.3.3	Temperature rise	Type DC	P
	ambient temperature 10-40 °C	25	
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		
	material of enclosure		
	Main circuits, test conditions:		N
	- conventional thermal current I _{th} (A)		
	- conventional enclosed thermal current I _{the} (A) ..		
	- cable/busbar cross-section (mm ²) / (mm)		
	- temperature rise of main circuit terminals (K)	<	
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
	Coils and electromagnets, test conditions:	DC	P
	- rated control supply voltage U _s (V)	220 24	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 40 ≤ 64	
	Starter	Tested with setting range 10 – 14 A	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	material of enclosure	Metal	
	Main circuits, test conditions: *Tested with 14A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	14 (25*)	
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- temperature rise of main circuit terminals (K)	≤ 62	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I_e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	DC	P
	rated control supply voltage U_s (V)	220 24	
	frequency (Hz)	DC DC	
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s	69 70	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	31 38	P
9.3.3.2.2	Relays and releases Setting Range 10 – 14 A		P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. compensated	
	trip class	10A	
	current setting I_{set} :	10 A 14 A	
	ambient temperature (°C)	25	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	cable/busbar cross-section (mm ²) / (mm)	2,5	
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A 14,7 A	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	No tripping No tripping	
		12 A 16,8 A	
		3:55 0:43	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A	21 A	
		0:22	0:08	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T_p (s)	72 A	100,8 A	
		2,1	2,5	
	Ambient temperature: - 5 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A	14,7 A	
		No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	12 A	16,8 A	
		22:10	1:45	
	for class 10A overlod relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A	21 A	
		0:36	0:12	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	72 A	100,8A	
	2,1	2,0	
	Ambient temperature: + 40 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	10,5 A	14,7 A	
	No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	12 A	16,8 A	
	0:50	0:12	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	15 A	21 A	
	0:08	0:05	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	72 A	100,8 A	
	2	2,2	
	Limits of operation of three-pole thermal overload relays energized on two poles:			P
	ambient temperature (°C)	25		
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	10 A / 9 A	14 A / 12,6 A	
	No tripping	No tripping	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h..... min:sec :	11,5 A / 0 A 16,1 A / 0 A 1:00 0:24	
9.3.3.4	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	
	- test Uimp main circuits (kV)	9,8 / 7	P
	- test Uimp auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	
	rated operational voltage Ue (V)	690	
	rated operational current Ie (A) or power (kW)	25A	
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 725 L2: 730 L3: 730	
	- test current I/Ie = 1,5 (A)	L1: 38 L2: 38 L3: 38	
	- power factor/time constant	L1: 0,78 L2: 0,78 L3: 0,79	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- on-time (ms)	160	
	- off-time (s)	9,8	
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	
	rated operational voltage U_e (V)	400V	
	rated operational current I_e (A) or power (kW)	12A	
	Conditions, make operations AC3/AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 426 L2: 425 L3: 427	
	- test current $I/I_e =$ (A)	L1: 192 L2: 193 L3: 192	
	- power factor/time constant	L1: 0,4 L2: 0,4 L3: 0,4	
	- on-time (ms)	100	
	- off-time (s)	10	
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Measured oscillatory frequency (kHz)	L1: 47,5 L2: 48 L3: 48	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	
	rated operational voltage U_e (V)	400	
	rated operational current I_e (A) or power (kW)	12A	
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 430 L2: 429 L3: 430	
	- test current $I/I_e =$ (A)	L1: 99 L2: 101 L3: 99	
	- power factor/time constant	L1: 0,42 L2: 0,42 L3: 0,42	
	- on-time (ms)	100	
	- off-time (s)	4	
	- number of make/break operations	6000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 37,5 L2: 38 L3: 38	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	
	rated operational voltage (V)	690	
	rated operational current I _e (A) or power (kW)	25A	
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 725 L2: 730 L3: 730	
	test current (A)	L1: 38 L2: 38 L3: 38	
	power factor/time constant	L1: 0,78 L2: 0,79 L3: 0,79	
	- on-time (ms)	160	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- off-time (s)	2,3	
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r": U12/16 0,4 -0,6A Represents setting ranges up to 11A		
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD, co-ordination type 1	25A / 500V	
	ratings of SCPD, co-ordination type 2	-	
	rated operational current Ie (A) AC-3	12A	
	prospective current "r" (kA)	1	
	test voltage (V)	L1: 424 L2: 423 L3: 425	
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	
	power factor	0,95	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² t _{da} (A ² s) / peak current I (A)	L1: 1750 A ² s / 807A L2: 2180 A ² s / 887 A L3: 1860 A ² s / 903 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² t _{da} (A ² s) / peak current I (A)	L1: 108 A ² s / 270 A L2: 695 A ² s / 586 A L3: 884 A ² s / 601 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
9.3.4.2.1	Test at de prospective current "r": U12/16 13 -18A Represents setting ranges higher 10A		
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD, co-ordination type 1	63A / 500V	
	ratings of SCPD, co-ordination type 2	-	
	rated operational current Ie (A) AC-3	12A	
	prospective current "r" (kA)	1	
	test voltage (V)	L1: 424 L2: 423 L3: 425	
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	
	power factor	0,95	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² t _{da} (A ² s) / peak current I (A)	L1: 20,8 kA ² s / 1330 A L2: 19,6 kA ² s / 1283 A L3: 23 kA ² s / 1210 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² t _{da} (A ² s) / peak current I (A)	L1: 22,1 kA ² s / 1260 A L2: 19,5 kA ² s / 1283 A L3: 21,4 kA ² s / 1306 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		
	ratings of SCPD, co-ordination type 1		
	ratings of SCPD, co-ordination type 2		
	rated operational current Ie (A) AC-3		
	prospective current "Iq" (kA)		
	test voltage (V)	L1: L2: L3:	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	r.m.s. test current (A)	L1: L2: L3:	
	peak current (A)	L1: L2: L3:	
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I_{dta} (A ² s)	L1: L2: L3:	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	
	rated operational current Ie (A) max. AC-3	12	
	test current (Ie) (A)	96	
	duration of test: 10 s	10s	
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements				P
Main Terminals Contactor (14A)				
		1	51	65
		3	57	65
		5	57	65
Main Terminal Overload Relay (14A)				
		2	53	65
		4	62	65
		6	57	65
Auxiliary Terminals Contactor (16A)				
		13	43	65
		14	42	65
Auxiliary Terminal Overload Relay (4A)				
		95	44	65
		96	40	65
Coil:				
	240V	50Hz	76	135
	24V + 10%	DC	64	135
	220V + 10%	DC	40	135
Type: KG	220V	DC	66	135



EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1: 266 L2: - L3: -	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- on-time (ms)	300	
	- operating cycles per minute	6	
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	
	- operating cycles per minute	15	
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		
	rated operational voltage Ue (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD	25A / 500V	
	prospective current (kA)	1	
	test voltage (V) U/Ue = 1,1 (V)	L1: 277 L2: 275 L3: 276	
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2t_{ta} (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	
	time interval between test (min. 3 min)		
	second making operation to closed switching elements: test I^2t_{ta} (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	
	time interval between test (min. 3 min)		
	third making operation to closed switching elements: test I^2t_{ta} (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No.	: 2.03.00356.1.0-K216/B&J
Tested by (+ signature).....	: Ing.J.Ainetter 
Approved by (+ signature)	: Ing.K.Farhofer 
Date of issue	: 02.02.2004
Testing laboratory	: Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address.....	: A – 1031 Vienna, Faradaygasse 3
Testing location.....	: as above
Applicant	: Benedict GmbH (Ω Benedikt & Jäger)
Address.....	: A – 1220 Vienna, Lieblgasse 7
Standard	: EN 60 947-4-1:2000-11
Test Report Form No.	: 69474-1A
Master TRF	: reference No. 69474-1A, dated 95-07
Copyright blank test report.....	: the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure	: CB-scheme
Procedure deviation	: N.A.
Non-standard test method	: N.A.
Type of test object	: Motor-Starter
Trademark	: Ω, Benedikt & Jäger
Model/type reference	: Kx2-16Axx + U12/16xxx
Manufacturer.....	: Ω Benedikt & Jäger
Rating	: AC1 25A 690V 50-60Hz AC3/AC4 16A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contactor K2-16A

K2-16A

IEC / EN60947-4-1	AC1=I _{th}				
VDE0660 AS3047-4-1	690V~ 25A				
AC2, AC3	220	380	415	500	690
V~	240	400	440	500	690
KW	5	7,5	8,5	10	7,5



MADE IN AUSTRIA

LISTED IND. CONT.
EQUIP. 9362

600V ac 25amp A800	96	97	98
max. v 120 200 240 480 600			
3ph hp	2	3	5
1ph 2p hp	1	2	3

SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NOT MORE THAN 5000 RMS SYMMETRICAL AMPS 600 VOLTS MAX. WHEN PROTECTED BY A FUSE RATED 50AMP
TIGHTENING TORQUE 8.1 lb.-in.
14AWG-10AWG
WIRE 60°C Cu ONLY

Overload Relay

U12/16E 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A

Typ 1" 25A **2,7-4A**
gl.(gG) Typ 2" 10A

600VA max. 4A
440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 9363
600V ac

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16A 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A

Typ 1" 25A **2,7-4A**
gl.(gG) Typ 2" 10A

600VA max. 4A
440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 9363
500V ac

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 500V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16EM

BENEDIKT & JÄGER

IEC / EN60947-4-1 VDE0660
690V~ 25A

U12/16EM

S. No. [redacted]

Rated Voltage	Rated Current	Rated Power	Rated Voltage	Rated Current	Rated Power
0.12 - 1.0A	0.12 - 1.0A	0.12 - 1.0A	0.12 - 1.0A	0.12 - 1.0A	0.12 - 1.0A
0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A
0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A
0.5 - 1.0A	0.5 - 1.0A	0.5 - 1.0A	0.5 - 1.0A	0.5 - 1.0A	0.5 - 1.0A

Made in Austria

U12/16EQ 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A

Typ 1" 25A **2,7-4A**
gl.(gG) Typ 2" 10A

600VA max. 4A
440V~ 95 | 97
690V~ 95 | 97

LISTED IND. CONT. EQ. 9363
600V ac

Made in Austria

U12/16U 4

IEC/EN60947 VDE0660 690V~
Auslöseklasse / Trip class: 10A

Typ 1" 25A **2,7-4A**
gl.(gG) Typ 2" 10A

690V~
600VA max. 4A

LISTED IND. CONT. EQ. 9363
600V ac

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600V max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.


Made in Austria

Photo:

K2-16A10 AC-operated


K2-16A10= DC-operated

KG2-16A10



Overload Relay:

U12/16E



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 1 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 25
- conventional enclosed thermal current I_{the} (A) : 25
- rated operational current I_e (A) : 25
- rated uninterrupted I_u (A) : 25
- utilization category..... : AC1, AC3, AC4

Short-circuit characteristic..... :

- rated prospective short-circuit current "r" (kA) : 1
- rated conditional short-circuit current I_q (kA) : 1

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : 1
- number and kind of contact elements : 1 NO or 1 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse: 25A up to 11A AC3/AC4
63A higher than 10A AC3/AC4

Possible test case verdicts:

- test case does not apply to the test object..... : N(A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HN' or 'HA'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:

Contactor

Kx2-16A x x

| | | >>> : 0, 1 : Number of NC auxiliary contacts
 | | | >>>> : 0, 1 : Number of NO auxiliary contacts
 | >>>> : G : DC coil supply (optional)

Overload Relay

U12/16 x x x

| | | >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /
 | | 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /
 | | 2,7 – 4 / 4 – 6 / 6 – 9 / 8 – 11 / 10 – 14 / 13 – 18 A
 | |
 | | >>>> : M ... With additional quick trip up to 4A (optional)
 | : Q ... Thermic quick trip up to 14A (optional)
 |
 | >>>> : U ... Change over auxiliary contacts
 : A ... Change over auxiliary contacts with autom. Reset
 : E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz
 6 – 600V 60Hz
 12 – 250V DC *

12V up to 24V: Double Winding Coil with Late Break Contact in series to coil.

25V up to 250V: Dropping Resistor with Late Break Contact in series to coil.

KG – type: Without Late Break Contact

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 25A, 690V AC3 AC4 16A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	1 kA Type '1' 63A/25A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C	Cover (grey)	P
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- le		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	—
	diameter of thread (mm)	M4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	—
	number of conductor of the smallest cross section	1	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	1,4	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	80	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Overload	P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5 6 // 1,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 // 6,4 9,5 // 6,4	—
	height between the equipment and the platen (mm)	279 // 260 279 // 260	—
	mass at the conductor(s) (kg)	0,7 // 0,3 1,4 // 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	50 // 30 80 // 30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,75 0,5	—
	maximum cross-sectional area of conductor (mm ²)	6 4	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	4	
	diameter of thread (mm)	M 3,5	
	torque (Nm)	0,8	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	0,75	
	number of conductor of the smallest cross section	2	
	diameter of bushing hole (mm)	6,4	
	height between the equipment and the platen (mm)	260	
	mass at the conductor(s) (kg)	0,4	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	30	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	4	
	number of conductor of the largest cross-sectional	2	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	0,9	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	4 // 2,5 1,5 // 0,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 6,4	—
	height between the equipment and the platen (mm)	279 260	—
	mass at the conductor(s) (kg)	0,9 // 0,7 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	60 // 50 40 // 30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,75 0,75	—
	maximum cross-sectional area of conductor (mm ²)	4 2,5	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals - Main circuit: - Auxiliary circuit	2T1, 4T2, 6T3 95-96, 97-98, 13-14, 21-22, A1, A2	P
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	—
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	—

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC and DC - KG	P
	ambient temperature 10-40 °C	25	—
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure		—
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		
	- conventional enclosed thermal current I _{the} (A) ..		
	- cable/busbar cross-section (mm ²) / (mm)		
	- temperature rise of main circuit terminals (K)	<	
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
	Coils and electromagnets, test conditions:	AC DC Type KG	P
	- rated control supply voltage U _s (V)	240 220	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 76 ≤ 66	
	Starter	Tested with setting range 13 – 18 A	
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	
	material of enclosure	Metal	
	Main circuits, test conditions: *Tested with 16A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	16 (25*)	
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²	
	- temperature rise of main circuit terminals (K)	≤ 59	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC Type KG	P
	rated control supply voltage U _s (V)	240 220	
	frequency (Hz)	50 DC	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	80	81	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	47	23	P
9.3.3.3	Temperature rise	Type DC		P
	ambient temperature 10-40 °C	25		—
	Contactor			N
	test enclosure W x H x D (mm x mm x mm)			—
	material of enclosure			—
	Main circuits, test conditions:			N
	- conventional thermal current I _{th} (A)			—
	- conventional enclosed thermal current I _{the} (A) ..			—
	- cable/busbar cross-section (mm ²) / (mm)			—
	- temperature rise of main circuit terminals (K)	<		—
	Auxiliary circuit, test conditions:			P
	- rated operation current I _e (A)	16		—
	- cable cross-section (mm ²)	2,5		—
	- temperature rise of auxiliary circuit terminals (K)	≤ 43		—
	Coils and electromagnets, test conditions:	DC		P
	- rated control supply voltage U _s (V)	220	24	—
	- Class of insulating material	F	F	—
	- temperature rise of coil and electromagnets (K) :	≤ 40	≤ 64	—
	Starter	Tested with setting range 13 – 18 A		
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115		—
	material of enclosure	Metal		—
	Main circuits, test conditions: *Tested with 16A because of max. Power consumption of Overload Relay			P
	- conventional thermal current I _{th} (A)	16 (25*)		—
	- cable/busbar cross-section (mm ²) / (mm)	2,5 mm ²		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- temperature rise of main circuit terminals (K)	≤ 59	—
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	—
	- cable cross-section (mm ²)	1	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 43	—
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	DC	P
	rated control supply voltage U _s (V)	220 24	—
	frequency (Hz)	DC DC	—
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U _s	69 70	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	31 38	P
9.3.3.2.2	Relays and releases	Setting Range 13 – 18 A	P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. compensated	—
	trip class	10A	—
	current setting I _{set} :	13 A 18 A	—
	ambient temperature (°C)	25	—
	test enclosure W x H x D (mm x mm x mm)	175 x 115 x 115	—
	cable/busbar cross-section (mm ²) / (mm)	2,5	—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	13,65 A 18,9 A No tripping No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	15,6 A 21,6 A 4:05 2:45	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	19,5 A	27 A	—
		0:31	0:18	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T_p (s)	93,6 A	129,6 A	—
	Ambient temperature: - 5 °C	2,5	2,3	
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	13,65 A	18,9 A	—
		No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	15,6 A	21,6 A	—
		28:35	2:25	
	for class 10A overlod relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	19,5 A	27 A	—
		1:07	0:27	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	93,6 A	129,6A	—
		3,1	2,6	—
	Ambient temperature: + 40 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	13,65 A	18,9 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	15,6 A	21,6 A	—
		1:10	1:15	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	19,5 A	27 A	—
		0:15	0:10	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	93,6 A	129,6 A	—
		2,9	2,1	—
	Limits of operation of three-pole thermal overload relays energized on two poles:			P
	ambient temperature (°C)	25		—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	13 A / 11,7 A	18 A / 16,2 A	—
		No tripping	No tripping	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h min:sec :	14,95 A / 0 A 20,7 A / 0 A 1:55 0:23	—
9.3.3.4	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	—
	- test Uimp main circuits (kV)	9,8 / 7	P
	- test Uimp auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	—
	rated operational voltage Ue (V)	690	—
	rated operational current Ie (A) or power (kW)	25A	—
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 725 L2: 730 L3: 730	—
	- test current I/Ie = 1,5 (A)	L1: 38 L2: 38 L3: 38	—
	- power factor/time constant	L1: 0,78 L2: 0,78 L3: 0,79	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- on-time (ms)	160	—
	- off-time (s)	9,8	—
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	—
	rated operational voltage U_e (V)	400V	—
	rated operational current I_e (A) or power (kW)	16A	—
	Conditions, make operations AC3/AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 426 L2: 425 L3: 427	—
	- test current $I/I_e =$ (A)	L1: 192 L2: 193 L3: 192	—
	- power factor/time constant	L1: 0,4 L2: 0,4 L3: 0,4	—
	- on-time (ms)	100	—
	- off-time (s)	10	—
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Measured oscillatory frequency (kHz)	L1: 47 L2: 48 L3: 48	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	—
	rated operational voltage U_e (V)	400	—
	rated operational current I_e (A) or power (kW)	16A	—
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 430 L2: 429 L3: 430	—
	- test current $I/I_e =$ (A)	L1: 99 L2: 101 L3: 99	—
	- power factor/time constant	L1: 0,42 L2: 0,42 L3: 0,42	—
	- on-time (ms)	100	—
	- off-time (s)	4	—
	- number of make/break operations	6000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 38 L2: 38 L3: 39	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	—
	rated operational voltage (V)	690	—
	rated operational current I _e (A) or power (kW)	25A	—
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 725 L2: 730 L3: 730	—
	test current (A)	L1: 38 L2: 38 L3: 38	—
	power factor/time constant	L1: 0,78 L2: 0,79 L3: 0,79	—
	- on-time (ms)	160	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- off-time (s)	2,3	—
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	—

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r": U12/16 0,4 -0,6A Represents setting ranges up to 11A		
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD, co-ordination type 1	25A / 500V	—
	ratings of SCPD, co-ordination type 2	-	—
	rated operational current Ie (A) AC-3	16A	—
	prospective current "r" (kA)	1	—
	test voltage (V)	L1: 424 L2: 423 L3: 425	—
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	—
	power factor	0,95	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dta (A ² s) /peak current I (A)	L1: 1750 A ² s / 807A L2: 2180 A ² s / 887 A L3: 1860 A ² s / 903 A	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dta (A ² s) /peak current I (A)	L1: 108 A ² s / 270 A L2: 695 A ² s / 586 A L3: 884 A ² s / 601 A	—
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	—
9.3.4.2.1	Test at de prospective current "r": U12/16 13 -18A Represents setting ranges higher 10A		
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD, co-ordination type 1	63A / 500V	—
	ratings of SCPD, co-ordination type 2	-	—
	rated operational current Ie (A) AC-3	16A	—
	prospective current "r" (kA)	1	—
	test voltage (V)	L1: 424 L2: 423 L3: 425	—
	r.m.s. test current (A)	L1: 1053 L2: 1087 L3: 1062	—
	peak current (A)	L1: 1457 L2: 1457 L3: 1378	—
	power factor	0,95	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2dt_a (A ² s) / peak current I (A)	L1: 20,8 kA ² s / 1330 A L2: 19,6 kA ² s / 1283 A L3: 23 kA ² s / 1210 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I^2dt_a (A ² s) / peak current I (A)	L1: 22,1 kA ² s / 1260 A L2: 19,5 kA ² s / 1283 A L3: 21,4 kA ² s / 1306 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		—
	ratings of SCPD, co-ordination type 1		—
	ratings of SCPD, co-ordination type 2		—
	rated operational current Ie (A) AC-3		—
	prospective current "Iq" (kA)		—
	test voltage (V)	L1: L2: L3:	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	r.m.s. test current (A)	L1: L2: L3:	
	peak current (A)	L1: L2: L3:	
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2dt_a (A ² s)	L1: L2: L3:	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	—
	rated operational current I _e (A) max. AC-3	16	—
	test current (I _e) (A)	128	—
	duration of test: 10 s	10s	—
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements			P	
temperature rise dT of part	No.	dT (K)	Required dT (K)	
Main Terminals Contactor (16A)	1	51	65	
	3	54	65	
	5	58	65	
Main Terminal Overload Relay (16A)	2	59	65	
	4	54	65	
	6	51	65	
Auxilixary Terminals Contactor (16A)	13	43	65	
	14	42	65	
Auxiliary Terminal Overload Relay (4A)	95	44	65	
	96	40	65	
Coil:	240V	50Hz	76	135
	24V + 10%	DC	64	135
	220V + 10%	DC	40	135
Type: KG	220V	DC	66	135

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict



EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1: 266 L2: - L3: -	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- on-time (ms)	300	
	- operating cycles per minute	6	
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	
	- operating cycles per minute	15	
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		
	rated operational voltage Ue (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD	25A / 500V	—
	prospective current (kA)	1	—
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	—
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	—
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	—
	time interval between test (min. 3 min)		—
	second making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	—
	time interval between test (min. 3 min)		—
	third making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	—
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No. :	2.03.00356.1.0-K223/B&J
Tested by (+ signature)..... :	Ing.J.Ainetter 
Approved by (+ signature)..... :	Ing.K.Farthofer 
Date of issue..... :	02.02.2004
Testing laboratory..... :	Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address..... :	A – 1031 Vienna, Faradaygasse 3
Testing location..... :	as above
Applicant..... :	Benedict GmbH (Ω Benedikt & Jäger)
Address..... :	A – 1220 Vienna, Lieblgasse 7
Standard..... :	EN 60 947-4-1:2000-11
Test Report Form No. :	69474 - 1A
Master TRF..... :	reference No. 69474-1A, dated 95-07
Copyright blank test report..... :	the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure..... :	CB-scheme
Procedure deviation..... :	N.A.
Non-standard test method..... :	N.A.
Type of test object..... :	Motor-Starter
Trademark..... :	Ω, Benedikt & Jäger
Model/type reference..... :	K2-23Axx + U12/16xxx
Manufacturer..... :	Ω Benedikt & Jäger
Rating..... :	AC1 45A 690V 50-60Hz AC3/AC4 23A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contactor K2-23A

K2-23A

IEC947-4-1 AS3847-4-1 VDE0660
EN60947-4-1 AC1 = I_{th} 45A 690V~

AC2, AC3	220	240	230	240	380	415	400	440	500	690
V~										
KW	8	7	11	12	15					

Made in Austria



LISTED IND. CONT. EQ. 93B3
600v ac 40amp A800

v	120	200	230	480	600
I _{th} 3ph	3	5	7.5	15	20
I _{th} 1ph 2p	1.5	3	3	-	-

UL: ASME A17.5 600v ac, 15FLA, 3ph, 500,000 cycles

WIRE 60/75°C Cu ONLY
TIGHT TORQUE 13.5 lb.-in.
14AWG - 14AWG - SYM. AMP. 600 VOLTS
10AWG - 8AWG - AC MAXIMUM. MAX. FUSE SIZE 60 AMP.

SUITABLE FOR USE ON A CIRCUIT OF DELIVERING 5000RMS
SYM. AMP. 600 VOLTS
AC MAXIMUM. MAX. FUSE SIZE 60 AMP.

Overload Relay

U12/16E 4



IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1* 2SA 2,7-4A
dL(gG) Typ 2* 10A

LISTED IND. CONT. EQ. 93B3
600v ac
Max. fuse size 15A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16A 4



IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1* 2SA 2,7-4A
dL(gG) Typ 2* 10A

LISTED IND. CONT. EQ. 93B3
600v ac
Max. fuse size 15A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16EM

BENEDIKT & JÄGER
IEC/EN60947-4-1 VDE0660
Ausstoßklasse / Trip class: 10A

U12/16EM

S. No. [redacted]

Rated Voltage	Rated Current	Rated Power	Rated Torque	Rated Speed	Rated Efficiency
0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A	0.12 - 0.25A
0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A	0.25 - 0.5A
0.5 - 1A	0.5 - 1A	0.5 - 1A	0.5 - 1A	0.5 - 1A	0.5 - 1A
1 - 2A	1 - 2A	1 - 2A	1 - 2A	1 - 2A	1 - 2A
2 - 5A	2 - 5A	2 - 5A	2 - 5A	2 - 5A	2 - 5A
5 - 10A	5 - 10A	5 - 10A	5 - 10A	5 - 10A	5 - 10A
10 - 15A	10 - 15A	10 - 15A	10 - 15A	10 - 15A	10 - 15A
15 - 20A	15 - 20A	15 - 20A	15 - 20A	15 - 20A	15 - 20A
20 - 25A	20 - 25A	20 - 25A	20 - 25A	20 - 25A	20 - 25A
25 - 30A	25 - 30A	25 - 30A	25 - 30A	25 - 30A	25 - 30A
30 - 35A	30 - 35A	30 - 35A	30 - 35A	30 - 35A	30 - 35A
35 - 40A	35 - 40A	35 - 40A	35 - 40A	35 - 40A	35 - 40A
40 - 45A	40 - 45A	40 - 45A	40 - 45A	40 - 45A	40 - 45A
45 - 50A	45 - 50A	45 - 50A	45 - 50A	45 - 50A	45 - 50A
50 - 55A	50 - 55A	50 - 55A	50 - 55A	50 - 55A	50 - 55A
55 - 60A	55 - 60A	55 - 60A	55 - 60A	55 - 60A	55 - 60A
60 - 65A	60 - 65A	60 - 65A	60 - 65A	60 - 65A	60 - 65A
65 - 70A	65 - 70A	65 - 70A	65 - 70A	65 - 70A	65 - 70A
70 - 75A	70 - 75A	70 - 75A	70 - 75A	70 - 75A	70 - 75A
75 - 80A	75 - 80A	75 - 80A	75 - 80A	75 - 80A	75 - 80A
80 - 85A	80 - 85A	80 - 85A	80 - 85A	80 - 85A	80 - 85A
85 - 90A	85 - 90A	85 - 90A	85 - 90A	85 - 90A	85 - 90A
90 - 95A	90 - 95A	90 - 95A	90 - 95A	90 - 95A	90 - 95A
95 - 100A	95 - 100A	95 - 100A	95 - 100A	95 - 100A	95 - 100A

U12/16EQ 4



IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1* 2SA 2,7-4A
dL(gG) Typ 2* 10A

LISTED IND. CONT. EQ. 93B3
600v ac
Max. fuse size 15A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

U12/16U 4




IEC/EN60947 VDE0660 690V~
Ausstoßklasse / Trip class: 10A
Type 1* 2SA 2,7-4A
dL(gG) Typ 2* 10A

LISTED IND. CONT. EQ. 93B3
600v ac
Max. fuse size 15A


Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Photo:

K2-23A10 AC-operated




K2-23A10= DC-operated



Overload Relay:

U12/16E



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 1 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V)..... : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 45
- conventional enclosed thermal current I_{the} (A) : 45
- rated operational current I_e (A) : 45
- rated uninterrupted I_u (A) : 45
- utilization category..... : AC1, AC3, AC4

Short-circuit characteristic..... :

- rated prospective short-circuit current "r" (kA) : 3
- rated conditional short-circuit current I_q (kA) : 3

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : 1
- number and kind of contact elements : 1 NO or 1 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse

Possible test case verdicts:

- test case does not apply to the test object..... : N(A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HN' or 'HA'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:

Contactor

K2-23A x x

| | | >>> : 0, 1 : Number of NC auxiliary contacts

| | >>>> : 0, 1 : Number of NO auxiliary contacts

Overload Relay

U12/16 x x x

| | | >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /

| | 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /

| | 2,7 – 4 / 4 – 6 / 6 – 9 / 8 – 11 / 10 – 14 / 13 – 18 /

| | 17 – 23 / 22 – 30 A

| |

| | >>>> : M ... With additional quick trip up to 4A (optional)

| : Q ... Thermic quick trip up to 14A (optional)

|

| >>>> : U ... Change over auxiliary contacts

: A ... Change over auxiliary contacts with autom. Reset

: E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz

6 – 600V 60Hz

12 – 250V DC

With Late Break Contact in series to coil.

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 45A, 690V AC3 AC4 23A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	3 kA Type '1' 80A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C		N
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- Ie		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	—
	diameter of thread (mm)	M4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	—
	number of conductor of the smallest cross section	1	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	1,4	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	80	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Overload	P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5 6 // 1,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 // 6,4 9,5 // 6,4	—
	height between the equipment and the platen (mm)	279 // 260 279 // 260	—
	mass at the conductor(s) (kg)	0,7 // 0,3 1,4 // 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		P
	force (N)	50 // 30 80 // 30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,75 0,5	—
	maximum cross-sectional area of conductor (mm ²)	6 4	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	10	—
	diameter of thread (mm)	M 4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	1,5	—
	number of conductor of the smallest cross section	2	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	40	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	10	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	90	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	10 // 2,5 6 // 1,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 9,5 / 6,4	—
	height between the equipment and the platen (mm)	279 279 / 260	—
	mass at the conductor(s) (kg)	2 // 0,7 1,4 / 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	90 // 50 80 // 40	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	2,5 1,5	—
	maximum cross-sectional area of conductor (mm ²)	10 6	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals - Main circuit: - Auxiliary circuit	2T1, 4T2, 6T3 95-96, 97-98, 13-14, 21-22, A1, A2	P
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
	if, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	—
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	—

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC DC	P
	ambient temperature 10-40 °C	24	—
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure		—
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		—
	- conventional enclosed thermal current I _{the} (A) ..		—
	- cable/busbar cross-section (mm ²) / (mm)		—
	- temperature rise of main circuit terminals (K)	<	—
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	—
	- cable cross-section (mm ²)	2,5	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 37	—
	Coils and electromagnets, test conditions:	AC	DC
	- rated control supply voltage U _s (V)	240	24
	- Class of insulating material	F	F
	- temperature rise of coil and electromagnets (K) :	≤ 71	≤ 55
	Starter	Tested with setting range 22 – 30 A	
	test enclosure W x H x D (mm x mm x mm)	Open Type	
	material of enclosure	None	
	Main circuits, test conditions: *Tested with 30A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	30 (45*)	—
	- cable/busbar cross-section (mm ²) / (mm)	6 mm ²	—
	- temperature rise of main circuit terminals (K)	≤ 65	—
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	—
	- cable cross-section (mm ²)	1	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	—
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC	DC
	rated control supply voltage U _s (V)	240	24
	frequency (Hz)	50	DC

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	76	64	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	53	33	P
9.3.3.2.2	Relays and releases	Setting Range 22 – 30 A		P
	Conditions for thermal and time-delay magnetic overload relays only:			p
	type of time-delay overload relay	Thermal, Temp. compensated		—
	trip class	10A		—
	current setting I _{set} :	22 A	30 A	—
	ambient temperature (°C)	24		—
	test enclosure W x H x D (mm x mm x mm)	None		—
	cable/busbar cross-section (mm ²) / (mm)	6		—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	—
		7:15	2:30	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	—
		0:45	0:15	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T _p (s)	158,4 A	216 A	—
		2,3	2,1	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	Ambient temperature: - 5 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	
		No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	
		25:10	1:20	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	
		1:04	0:20	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	158,4 A	216A	
		2,8	2,1	
	Ambient temperature: + 40 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	
		No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	
		3:40	3:20	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	
		0:20	0:28	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N	—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	158,4 A 216 A 2,2 2,4	—
	Limits of operation of three-pole thermal overload relays energized on two poles:		P
	ambient temperature (°C)	25	—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	22 A / 19,8 A 30 A / 27 A No tripping No tripping	—
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h	25,3 A / 0 A 34,5 A / 0 A 0:20 0:11	—
9.3.3.4	Test of dielectric properties, impulse withstand voltage (U_{imp} indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	—
	- test U_{imp} main circuits (kV)	9,8 / 7	P
	- test U_{imp} auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (U_{imp} not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	—
	rated operational voltage Ue (V)	690	—
	rated operational current Ie (A) or power (kW)	45A	—
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 740 L2: 740 L3: 738	—
	- test current I/Ie = 1,5 (A)	L1: 78 L2: 77 L3: 78	—
	- power factor/time constant	L1: 0,83 L2: 0,82 L3: 0,83	—
	- on-time (ms)	160	—
	- off-time (s)	9,8	—
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	—
	rated operational voltage Ue (V)	400V	—
	rated operational current Ie (A) or power (kW)	23A	—
	Conditions, make operations AC3/AC4 only:		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: 425 L2: 424 L3: 425	—
	- test current $I/I_e =$ (A)	L1: 364 L2: 364 L3: 363	—
	- power factor/time constant	L1: 0,45 L2: 0,44 L3: 0,45	—
	- on-time (ms)	100	—
	- off-time (s)	10	—
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 53 L2: 54 L3: 53	
	Factor γ	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	—
	rated operational voltage U_e (V)	400	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	rated operational current I_e (A) or power (kW)	23A	—
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 424 L2: 422 L3: 425	—
	- test current $I/I_e =$ (A)	L1: 180 L2: 181 L3: 180	—
	- power factor/time constant	L1: 0,4 L2: 0,4 L3: 0,4	—
	- on-time (ms)	100	—
	- off-time (s)	4	—
	- number of make/break operations	6000	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 45,5 L2: 46 L3: 46	
	Factor γ	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	utilization category	AC1	—
	rated operational voltage (V)	690	—
	rated operational current I _e (A) or power (kW)	45A	—
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 725 L2: 730 L3: 730	—
	test current (A)	L1: 52 L2: 53 L3: 53	—
	power factor/time constant	L1: 0,82 L2: 0,81 L3: 0,80	—
	- on-time (ms)	160	—
	- off-time (s)	2,3	—
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 U _e + 1000 V) for 1 min (V)	2380	—

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r":	U12/16 22 -30A	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	type of SCPD	Siemens NH00 gL / gG	—
	ratings of SCPD, co-ordination type 1	80A / 500V	—
	ratings of SCPD, co-ordination type 2	-	—
	rated operational current I_e (A) AC-3	23A	—
	prospective current "r" (kA)	3	—
	test voltage (V)	L1: 545 L2: 543 L3: 545	—
	r.m.s. test current (A)	L1: 3040 L2: 3090 L3: 3110	—
	peak current (A)	L1: 4350 L2: 4360 L3: 3910	—
	power factor	0,9	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2dt_a (A ² s) / peak current I (A)	L1: 20,1 kA ² s / 2930A L2: 23,6 kA ² s / 2930 A L3: 20,0 kA ² s / 3450 A	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I^2dt_a (A ² s) / peak current I (A)	L1: 18,6 kA ² s / 2850 A L2: 23,5 kA ² s / 2850 A L3: 21,3 kA ² s / 3445 A	—
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		—
	ratings of SCPD, co-ordination type 1		—
	ratings of SCPD, co-ordination type 2		—
	rated operational current Ie (A) AC-3		—
	prospective current "Iq" (kA)		—
	test voltage (V)	L1: L2: L3:	—
	r.m.s. test current (A)	L1: L2: L3:	—
	peak current (A)	L1: L2: L3:	—
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² t _{da} (A ² s)	L1: L2: L3:	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	—
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	—
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	—
	rated operational current Ie (A) max. AC-3	23	—
	test current (Ie) (A)	184	—
	duration of test: 10 s	10s	—
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements			P
temperature rise dT of part:	No.	dT (K)	Required dT (K)
Main Terminals Contactor (30A)	1	60	65
	3	60	65
	5	65	65

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark	Verdict	
	Main Terminal Overload Relay (30A)	2	63	65
		4	63	65
		6	63	65
	Auxiliary Terminals Contactor (16A)	13	48	65
		14	48	65
	Auxiliary Terminal Overload Relay (4A)	95	40	65
		96	35	65
Coil:	240V	50Hz	71	135
	24V + 10%	DC	55	135



EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	—
	rated operational voltage U_e (V)	240	—
	rated operational current I_e (A) or power (kW)	12	—
	Conditions, make/break operations:		
	- test voltage $U/U_e = 1,1$ (V)	L1: 266 L2: - L3: -	—
	- power factor/time constant	L1: 0,31 L2: - L3: -	—
	- make operations: test current I/I_e (A)	L1: 123 L2: - L3: -	—
	- break operations: test current I/I_e (A)	L1: 123 L2: - L3: -	—
	- on-time (ms)	300	—
	- operating cycles per minute	6	—
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	—
	rated operational voltage Ue (V)	240	—
	rated operational current Ie (A) or power (kW)	12	—
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	—
	- power factor/time constant	L1: 0,31 L2: - L3: -	—
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	—
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	—
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	—
	- operating cycles per minute	15	—
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		—
	rated operational voltage Ue (V)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD	25A / 500V	—
	prospective current (kA)	1	—
	test voltage (V) U/Ue = 1,1 (V)	L1: 277 L2: 275 L3: 276	—
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	—
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dt (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	—
	time interval between test (min. 3 min)		—
	second making operation to closed switching elements: test I^2dt (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	—
	time interval between test (min. 3 min)		—
	third making operation to closed switching elements: test I^2dt (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	—
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No. :	2.03.00356.1.0-K230/B&J
Tested by (+ signature)..... :	Ing.J.Ainetter 
Approved by (+ signature) :	Ing.K.Farhofer 
Date of issue..... :	02.02.2004
Testing laboratory..... :	Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address..... :	A – 1031 Vienna, Faradaygasse 3
Testing location..... :	as above
Applicant..... :	Benedict GmbH (Ω Benedikt & Jäger)
Address..... :	A – 1220 Vienna, Lieblgasse 7
Standard..... :	EN 60 947-4-1:2000-11
Test Report Form No..... :	69474-1A
Master TRF..... :	reference No. 69474-1A, dated 95-07
Copyright blank test report..... :	the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure..... :	CB-scheme
Procedure deviation..... :	N.A.
Non-standard test method..... :	N.A.
Type of test object..... :	Motor-Starter
Trademark..... :	Ω, Benedikt & Jäger
Model/type reference..... :	K2-30Axx + U12/16xxx
Manufacturer..... :	Ω Benedikt & Jäger
Rating..... :	AC1 50A 690V 50-60Hz AC3/AC4 30A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contactor K2-30A

K2-30A

IEC947-4-1 AS3947-4-1 VDE0660
EN60947-4-1 AC1 = I_n 50A 690V~

AC2, AC3	220	380	415	500
V~	230	240	400	440
kW	8,5	9	15	18
			18	18,5



Made in Austria

LISTED IND. CONT. EQ. 93B2

v	120	200	230	480	600
hp 3ph	5	7.5	10	20	25
hp 1ph 2p	2	3	5	-	-

ASME A17.5 600v ac, 22FLA, 3ph, 500,000 cycles

WIRE 60/75°C Cu ONLY
TIGHT TORQUE 13.5 lb.-in.

SUITABLE FOR USE ON A CIRCUIT OF DELIVERING 5000RMS SYM. AMP 600 VOLTS AC MAXIMUM. MAX. FUSE SIZE 110 AMP.



Overload Relay

U12/16E 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A

Typ 1" 25A **2,7-4A**
dI (pG) Typ 2" 10A

600VA max. 4A
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
600v ac

150v 95
600v 95

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16A 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A

Typ 1" 25A **2,7-4A**
dI (pG) Typ 2" 10A

600VA max. 4A
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
500v ac

150v 95
500va 95

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 500v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16EM

BENECKT & JÄGER

IEC/EN60947-4-1 VDE0660
Auslösekategorie / Trip class: 10A

U12/16EM

S. No. [redacted]

Number	Current	Power	Current	Power
0.12	0.12	0.12	0.12	0.12
0.15	0.15	0.15	0.15	0.15
0.2	0.2	0.2	0.2	0.2
0.25	0.25	0.25	0.25	0.25
0.3	0.3	0.3	0.3	0.3
0.4	0.4	0.4	0.4	0.4
0.5	0.5	0.5	0.5	0.5
0.6	0.6	0.6	0.6	0.6
0.8	0.8	0.8	0.8	0.8
1.0	1.0	1.0	1.0	1.0
1.2	1.2	1.2	1.2	1.2
1.5	1.5	1.5	1.5	1.5
2.0	2.0	2.0	2.0	2.0
2.5	2.5	2.5	2.5	2.5
3.0	3.0	3.0	3.0	3.0
4.0	4.0	4.0	4.0	4.0
5.0	5.0	5.0	5.0	5.0
6.0	6.0	6.0	6.0	6.0
8.0	8.0	8.0	8.0	8.0
10.0	10.0	10.0	10.0	10.0

690V~ 0/R
600VA max. 4A

Made in Austria

U12/16EQ 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A

Typ 1" 25A **2,7-4A**
dI (pG) Typ 2" 10A

600VA max. 4A
440V~ 95
690V~ 95

LISTED IND. CONT. EQ. 93B3
500v ac

150v 95
500va 95

Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 500v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.

Made in Austria

U12/16U 4



IEC/EN60947 VDE0660 690V~
Auslösekategorie / Trip class: 10A

Typ 1" 25A **2,7-4A**
dI (pG) Typ 2" 10A

690V~ 0/R
600VA max. 4A

LISTED IND. CONT. EQ. 93B3
600v ac

150v 95
600v 95


Max. fuse size **15A**
500va max. 4A

Suitable for use on a circuit capable of delivering not more than 5kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.


Made in Austria

Photo:

K2-30A10 AC-operated




K2-30A10= DC-operated



Overload Relay:

U12/16E



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 1 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 50
- conventional enclosed thermal current I_{the} (A) : 50
- rated operational current I_e (A) : 50
- rated uninterrupted I_u (A) : 50
- utilization category..... : AC1, AC3, AC4

Short-circuit characteristic..... :

- rated prospective short-circuit current "r" (kA) : 3
- rated conditional short-circuit current I_q (kA) : 3

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : 1
- number and kind of contact elements : 1 NO or 1 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse

Possible test case verdicts:

- test case does not apply to the test object..... : N(.A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) Relevant tests have been performed with or without 'snap on auxiliary contact block' Typ 'HN' or 'HA'.

3) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:

Contactor

K2-30A x x

I I I >>> : 0, 1 : Number of NC auxiliary contacts

I I >>>> : 0, 1 : Number of NO auxiliary contacts

Overload Relay

U12/16 x x x

I I I >>>> : Setting range 0,12 – 0,18 / 0,18 – 0,27 / 0,27 – 0,4 / 0,4 – 0,6 /

I I 0,6 – 0,9 / 0,8 – 1,2 / 1,2 – 1,8 / 1,8 – 2,7 /

I I 2,7 – 4 / 4 – 6 / 6 – 9 / 8 – 11 / 10 – 14 / 13 – 18 /

I I 17 – 23 / 22 – 30 A

I I

I I >>>> : M ... With additional quick trip up to 4A (optional)

I : Q ... Thermic quick trip up to 14A (optional)

I

I >>>> : U ... Change over auxiliary contacts

: A ... Change over auxiliary contacts with autom. Reset

: E ... 1 NC and 1 NO auxiliary contact

Control Circuit Voltage:

6 – 550V 50Hz

6 – 600V 60Hz

12 – 250V DC

With Late Break Contact in series to coil.

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 50A, 690V AC3 AC4 30A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC4, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	3 kA Type '1' 80A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black)	P
	- other: 650°C		N
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- le		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Uimp is given as:	8 kV	
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Overload	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4.2	Mechanical strength of terminals		P
	maximum cross-sectional area of conductor (mm ²)	6	—
	diameter of thread (mm)	M4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		P
	conductor of the smallest cross-sectional area (mm ²)	0,5	—
	number of conductor of the smallest cross section	1	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,3	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		P
	force (N)	30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		P
	conductor of the largest cross-sectional area (mm ²)	6	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	1,4	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			P
	force (N)	80		—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Flexion test	Overload		P
	conductor of the largest and smallest cross-sectional area (mm ²)	2,5 // 0,5	6 // 1,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1	1 // 1	—
	diameter of bushing hole (mm)	9,5 // 6,4	9,5 // 6,4	—
	height between the equipment and the platen (mm)	279 // 260	279 // 260	—
	mass at the conductor(s) (kg)	0,7 // 0,3	1,4 // 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			P
	force (N)	50 // 30	80 // 30	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
8.1.7.2	Connecting capacity			P
	type of conductors	Rigid	Flexible	—
	minimum cross-sectional area of conductor (mm ²)	0,75	0,5	—
	maximum cross-sectional area of conductor (mm ²)	6	4	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2	2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	10	—
	diameter of thread (mm)	M 4	—
	torque (Nm)	1,2	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	1,5	—
	number of conductor of the smallest cross section	2	—
	diameter of bushing hole (mm)	6,4	—
	height between the equipment and the platen (mm)	260	—
	mass at the conductor(s) (kg)	0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	40	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	10	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	90	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	10 // 2,5 6 // 1,5	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 // 1 1 // 1	—
	diameter of bushing hole (mm)	9,5 9,5 / 6,4	—
	height between the equipment and the platen (mm)	279 279 / 260	—
	mass at the conductor(s) (kg)	2 // 0,7 1,4 / 0,4	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	90 // 50 80 // 40	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	2,5 1,5	—
	maximum cross-sectional area of conductor (mm ²)	10 6	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals - Main circuit:: - Auxiliary circuit	2T1, 4T2, 6T3 95-96, 97-98, 13-14, 21-22, A1, A2	P
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	—
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	—

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC DC	P
	ambient temperature 10-40 °C	24	—
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure		—
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)		—
	- conventional enclosed thermal current I _{the} (A) ..		—
	- cable/busbar cross-section (mm ²) / (mm)		—
	- temperature rise of main circuit terminals (K)	<	—
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	—
	- cable cross-section (mm ²)	2,5	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 37	—
	Coils and electromagnets, test conditions:	AC DC	P
	- rated control supply voltage U _s (V)	240 24	—
	- Class of insulating material	F F	—
	- temperature rise of coil and electromagnets (K) :	≤ 71 ≤ 55	—
	Starter	Tested with setting range 22 – 30 A	
	test enclosure W x H x D (mm x mm x mm)	Open Type	—
	material of enclosure	None	—
	Main circuits, test conditions: *Tested with 30A because of max. Power consumption of Overload Relay		P
	- conventional thermal current I _{th} (A)	30 (45*)	—
	- cable/busbar cross-section (mm ²) / (mm)	6 mm ²	—
	- temperature rise of main circuit terminals (K)	≤ 65	—
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	—
	- cable cross-section (mm ²)	1	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	—
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC	P
	rated control supply voltage U _s (V)	240 24	—
	frequency (Hz)	50 DC	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	76	64	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	53	33	P
9.3.3.2.2	Relays and releases	Setting Range 22 – 30 A		P
	Conditions for thermal and time-delay magnetic overload relays only:			p
	type of time-delay overload relay	Thermal, Temp. compensated		
	trip class	10A		
	current settingI _{set} :	22 A	30 A	
	ambient temperature (°C)	24		
	test enclosure W x H x D (mm x mm x mm)	None		
	cable/busbar cross-section (mm ²) / (mm)	6		
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	7:15	2:30	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	0:45	0:15	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T _p (s)	158,4 A	216 A	
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$, starting from the cold state; test current; tripping time T _p (s)	2,3	2,1	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	Ambient temperature: - 5 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	—
		25:10	1:20	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	—
		1:04	0:20	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N		—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10s$ starting from the cold state; test current; tripping time T_p (s)	158,4 A	216A	—
		2,8	2,1	—
	Ambient temperature: + 40 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	23,1 A	31,5 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	26,4 A	36 A	—
		3:40	3:20	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	33 A	45 A	—
		0:20	0:28	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	N	—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $2 < T_p \leq 10$ starting from the cold state; test current; tripping time T_p (s)	158,4 A 216 A 2,2 2,4	—
	Limits of operation of three-pole thermal overload relays energized on two poles:		P
	ambient temperature (°C)	25	—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	22 A / 19,8 A 30 A / 27 A No tripping No tripping	—
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h	25,3 A / 0 A 34,5 A / 0 A 0:20 0:11	—
9.3.3.4	Test of dielectric properties, impulse withstand voltage (U_{imp} indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	—
	- test U_{imp} main circuits (kV)	9,8 / 7	P
	- test U_{imp} auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (U_{imp} not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		N
	- control and auxiliary circuits, test voltage for 1 min (V)		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	—
	rated operational voltage Ue (V)	690	—
	rated operational current Ie (A) or power (kW)	50A	—
	Conditions, make/break operations AC-1 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 740 L2: 740 L3: 738	—
	- test current I/Ie = 1,5 (A)	L1: 78 L2: 77 L3: 78	—
	- power factor/time constant	L1: 0,83 L2: 0,82 L3: 0,83	—
	- on-time (ms)	160	—
	- off-time (s)	9,8	—
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P
	utilization category (AC-3 or AC-4)	AC4	—
	rated operational voltage Ue (V)	400V	—
	rated operational current Ie (A) or power (kW)	30A	—
	Conditions, make operations AC3/AC4 only:		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: 425 L2: 424 L3: 425	
	- test current $I/I_e =$ (A)	L1: 364 L2: 364 L3: 363	
	- power factor/time constant	L1: 0,45 L2: 0,44 L3: 0,45	
	- on-time (ms)	100	
	- off-time (s)	10	
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 53 L2: 54 L3: 53	
	Factor γ	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC4	
	rated operational voltage U_e (V)	400	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	rated operational current I_e (A) or power (kW):	30A	—
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 424 L2: 422 L3: 425	—
	- test current $I/I_e =$ (A)	L1: 180 L2: 181 L3: 180	—
	- power factor/time constant	L1: 0,4 L2: 0,4 L3: 0,4	—
	- on-time (ms)	100	—
	- off-time (s)	4	—
	- number of make/break operations	6000	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 45,5 L2: 46 L3: 46	
	Factor γ	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	utilization category	AC1	—
	rated operational voltage (V)	690	—
	rated operational current I _e (A) or power (kW)	50A	—
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 725 L2: 730 L3: 730	—
	test current (A)	L1: 52 L2: 53 L3: 53	—
	power factor/time constant	L1: 0,82 L2: 0,81 L3: 0,80	—
	- on-time (ms)	160	—
	- off-time (s)	2,3	—
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Dielectric verification:		P
	test voltage (2 U _e + 1000 V) for 1 min (V)	2380	—

9.3.4	TEST SEQUENCE III	
	Performance under short-circuit conditions	
9.3.4.2.1	Test at de prospective current "r": U12/16 22 -30A	

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
	type of SCPD	Siemens NH00 gL / gG	—
	ratings of SCPD, co-ordination type 1	80A / 500V	—
	ratings of SCPD, co-ordination type 2	-	—
	rated operational current I_e (A) AC-3	30A	—
	prospective current "r" (kA)	3	—
	test voltage (V)	L1: 545 L2: 543 L3: 545	—
	r.m.s. test current (A)	L1: 3040 L2: 3090 L3: 3110	—
	peak current (A)	L1: 4350 L2: 4360 L3: 3910	—
	power factor	0,9	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2dt_a (A ² s) / peak current I (A)	L1: 20,1 kA ² s / 2930A L2: 23,6 kA ² s / 2930 A L3: 20,0 kA ² s / 3450 A	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I^2dt_a (A ² s) / peak current I (A)	L1: 18,6 kA ² s / 2850 A L2: 23,5 kA ² s / 2850 A L3: 21,3 kA ² s / 3445 A	—
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—
9.3.4.2.2	Test at the rated conditional short-circuit current " $I_q \leq SCC \cdot r$ "		N
	type of SCPD		—
	ratings of SCPD, co-ordination type 1		—
	ratings of SCPD, co-ordination type 2		—
	rated operational current I_e (A) AC-3		—
	prospective current " I_q " (kA)		—
	test voltage (V)	L1: L2: L3:	—
	r.m.s. test current (A)	L1: L2: L3:	—
	peak current (A)	L1: L2: L3:	—
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I^2dt_a (A ² s)	L1: L2: L3:	—
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	—
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	—
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	—
	rated operational current Ie (A) max. AC-3	30	—
	test current (Ie) (A)	240	—
	duration of test: 10 s	10s	—
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements			P
temperature rise dT of part:	No.	dT (K)	Required dT (K)
Main Terminals Contactor (30A)	1	60	65
	3	60	65
	5	65	65



EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark	Verdict	
	Main Terminal Overload Relay (30A)	2	63	65
		4	63	65
		6	63	65
	Auxiliary Terminals Contactor (16A)	13	48	65
		14	48	65
	Auxiliary Terminal Overload Relay (4A)	95	40	65
		96	35	65
Coil:	240V	50Hz	71	135
	24V + 10%	DC	55	135

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1: 266 L2: - L3: -	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- on-time (ms)	300	
	- operating cycles per minute	6	
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	—
	rated operational voltage Ue (V)	240	—
	rated operational current Ie (A) or power (kW)	12	—
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	—
	- power factor/time constant	L1: 0,31 L2: - L3: -	—
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	—
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	—
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	—
	- operating cycles per minute	15	—
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		—
	rated operational voltage Ue (V)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	—
	ratings of SCPD	25A / 500V	—
	prospective current (kA)	1	—
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	—
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	—
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	—
	time interval between test (min. 3 min)		—
	second making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	—
	time interval between test (min. 3 min)		—
	third making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	—
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No. :	2.03.00356.1.0-K85/B&J
Tested by (+ signature)..... :	Ing.J.Ainetter 
Approved by (+ signature) :	Ing.K.Farthofer 
Date of issue..... :	02.02.2004
Testing laboratory..... :	Österreichische Forschungs- und Prüfbüro Arsenal Ges.m.b.H
Address..... :	A – 1031 Vienna, Faradaygasse 3
Testing location..... :	as above
Applicant..... :	Benedict GmbH (Ω Benedikt & Jäger)
Address..... :	A – 1220 Vienna, Liebiggasse 7
Standard..... :	EN 60 947-4-1:2000-11
Test Report Form No. :	69474-1A
Master TRF..... :	reference No. 69474-1A, dated 95-07
Copyright blank test report..... :	the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure..... :	CB-scheme
Procedure deviation..... :	N.A.
Non-standard test method..... :	N.A.
Type of test object..... :	Motor-Starter
Trademark..... :	Ω, Benedikt & Jäger
Model/type reference..... :	K85Axx + U85x
Manufacturer..... :	Ω Benedikt & Jäger
Rating..... :	AC1 150A 690V 50-60Hz AC3/AC4 85A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contacteur K85A

1 L1

3 L2

5 L3



K85

IEC/EN60947-4-1
VDE0660

AC1 I_n 150A U_e 850V~
AC2, AC3

220 - 230V~	25kW
240V~	27kW
380 - 400V~	45kW
415 - 440V~	49kW
500V~	55kW
660 - 690V~	55kW

Made in Austria

WIRE 75°C Cu ONLY
TIGHTENING TORQUE 162 lb.-in.
3 AWG - 0 AWG SINGLE
SUITABLE FOR USE ON A CIRCUIT
CAPABLE OF DELIVERING NOT
MORE THAN 10000 RMS
SYMMETRICAL AMPERES.
600 VOLTS MAXIMUM
WHEN PROTECTED BY A
FUSE RATED 300 AMP.

LISTED IND. CONT. EQ. 93B2

	Motor load	
	3ph ac	1ph ac
115 v	15 hp	8 hp
230 v	35 hp	20 hp
460 v	65 hp	-
575 v	85 hp	-
600 v	125 amp	-

Aux. cont. A600

2 T1

4 T2

6 T3


Overload Relay U85 90

IEC/EN60947 VDE0660 750V~
Auslöseklasse / Trip class: 10A

entspr. Leitung **60-90A**
adequate to conductor

600VA
max. 4A

Made in
Austria




LISTED IND. CONT. EQ. 93B3

Fuse size max. **300A**


Suitable for use on a circuit capable of delivering not more than 10kA rms. sym. 600v max. Numbers on dial are full load motor currents. Tripping current is 125% of numbers on dial.



Photo:
Contactor K85



Overload Relay U85



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles..... Contactor: 3 Main 4 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 150
- conventional enclosed thermal current I_{the} (A) : 150
- rated operational current I_e (A) : 150
- rated uninterrupted I_u (A) : 150
- utilization category..... : AC1, AC3

Short-circuit characteristic :

- rated prospective short-circuit current "r" (kA) : 5
- rated conditional short-circuit current I_q (kA) : 5

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : Max. 4
- number and kind of contact elements : 2 NO and 2 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse

Possible test case verdicts:

- test case does not apply to the test object..... : N(.A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

**2) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11)
+ A1 (2002-09).**

Ordering key:

Contactor

K85A x x x

I I I >>>> : = : DC Supply (optional)
 I I >>>> : 0, 1, 2, 3, 4 : Number of NC auxiliary contacts
 I >>>> : 0, 1, 2, 3, 4 : Number of NO auxiliary contacts

Overload Relay

U85 x

I >>>> : Setting range 60 – 90 / 80 – 120 A

Control Circuit Voltage:

6 – 550V 50Hz

6 – 600V 60Hz

12 – 250V DC

With Late Break Contact in series to coil.

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 150A, 690V AC3 85A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	5 kA Type '1' 250A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black) Cover (grey)	P
	- other: 650°C		N
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	
	- nominal voltage of supply system	400 / 690V	
	- overvoltage category	IV	
	- pollution degree	3	
	- field-in or homogeneous	Inhomogeneous	
	- minimum clearances (mm)	8	
	- measured clearances (mm)	≥10	
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		
	- Ie		
	- minimum clearances L-L/L-A (mm)		
	- measured clearances L-L/L-A (mm)		
	Creepage distances		
	Uimp is given as:	8 kV	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals: Contactor		
8.2.4.2	Mechanical strength of terminals		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	maximum cross-sectional area of conductor (mm ²)	70	
	diameter of thread (mm)	M 8	
	torque (Nm)	3,5	
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	10	
	number of conductor of the smallest cross section	1	
	diameter of bushing hole (mm)	9,5	
	height between the equipment and the platen (mm)	279	
	mass at the conductor(s) (kg)	2	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	90	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	70	
	number of conductor of the largest cross-sectional	1	
	diameter of bushing hole (mm)	19,1	
	height between the equipment and the platen (mm)	368	
	mass at the conductor(s) (kg)	14	

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			
	force (N)	285		
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Flexion test	Contactor		
	conductor of the largest and smallest cross-sectional area (mm ²)	10	70	
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1	1	
	diameter of bushing hole (mm)	9,5	19,1	
	height between the equipment and the platen (mm)	279	368	
	mass at the conductor(s) (kg)	2	14	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit			P
	Pull-out test			
	force (N)	90	285	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit			P
8.1.7.2	Connecting capacity			P
	type of conductors	Semi Rigid	Flexible	
	minimum cross-sectional area of conductor (mm ²)	10	16	
	maximum cross-sectional area of conductor (mm ²)	70	50	
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr.		
		2	2	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals		P
	- Main circuit::	-	
	- Auxiliary circuit	95-96, 97-98, 13-14, 21- 22, 31-32, 43-44, A1, A2	
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	

9.3.1.a	TEST SEQUENCE I			
9.3.3.3	Temperature rise	Type AC	DC	P
	ambient temperature 10-40 °C	25		
	Contactor			N
	test enclosure W x H x D (mm x mm x mm)	350 x 175 x 145		
	material of enclosure	Metal		
	Main circuits, test conditions: * Tested with 170A			N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)	150	
	- conventional enclosed thermal current I _{the} (A) ..	150	
	- cable/busbar cross-section (mm ²) / (mm)	50 / 70*	
	- temperature rise of main circuit terminals (K)	≤ 60	
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	
	- cable cross-section (mm ²)	2,5	
	- temperature rise of auxiliary circuit terminals (K)	≤ 42	
	Coils and electromagnets, test conditions:	AC DC	P
	- rated control supply voltage U _s (V)	240 24	
	- Class of insulating material	F F	
	- temperature rise of coil and electromagnets (K) :	≤ 70 ≤ 60	
	Starter	Tested with setting range 60 – 90 A	
	test enclosure W x H x D (mm x mm x mm)	Open Type	
	material of enclosure	None	
	Main circuits, test conditions: *AC1 rating 150A tested with 170A		P
	- conventional thermal current I _{th} (A)	150 *	
	- cable/busbar cross-section (mm ²) / (mm)	50 / 70* mm ²	
	- temperature rise of main circuit terminals (K)	≤ 60 Temp. Rise on Contactor terminals only. Worst Case AC1 150A (Tested with 170A) instead of AC3 85A	
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	
	- cable cross-section (mm ²)	1	
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	rated control supply voltage U_s (V)	240 24	—
	frequency (Hz)	50 DC	—
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s	76 65	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	57 25	P
9.3.3.2.2	Relays and releases Setting Range 60 – 90 A		P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. Compensated with current Transformer	—
	trip class	20	—
	current setting I_{set} :	60 A 90 A	—
	ambient temperature (°C)	24	—
	test enclosure W x H x D (mm x mm x mm)	None	—
	cable/busbar cross-section (mm ²) / (mm)		—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	63 A 94,5 A No tripping No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	72 A 108 A 1:55 1:15	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	N	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time min:sec :	90 A 135 A 0:15 0:11	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20$, starting from the cold state; test current; tripping time T_p (s)	432 A	648 A	
 min:sec :	13	19	
	Ambient temperature: - 5 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	63 A	94,5 A	
 min:sec :	No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	72 A	108 A	
 min:sec :	15:40	2:55	
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current			
 min:sec :	N		
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	90	135 A	
 min:sec :	0:55	0:40	
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20$ s starting from the cold state; test current; tripping time T_p (s)	432 A	648 A	
 min:sec :	16	20	
	Ambient temperature: + 40 °C			
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	63 A	94,5 A	
 min:sec :	No tripping	No tripping	
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	72 A	108 A	
 min:sec :	1:20	1:30	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	N	
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time min:sec :	90 A 135 A 0:12 0:40	
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20$ starting from the cold state; test current; tripping time T_p (s)	432 A 648 A 15 19	
	Limits of operation of three-pole thermal overload relays energized on two poles:		P
	ambient temperature (°C)	25	
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	64 A / 54 A 90 A / 81 A No tripping No tripping	
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h	69 A / 0 A 103,5 A / 0 A 1:30 0:55	
9.3.3.4	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	
	- test Uimp main circuits (kV)	9,8 / 7	P
	- test Uimp auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		
	- main circuits, test voltage for 1 min (V)		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	
	rated operational voltage U_e (V)	690	
	rated operational current I_e (A) or power (kW)	150A	
	Conditions, make/break operations AC-1 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 740 L2: 739 L3: 739	
	- test current $I/I_e = 1,5$ (A)	L1: 262 L2: 262 L3: 263	
	- power factor/time constant	L1: 0,8 L2: 0,79 L3: 0,8	
	- on-time (ms)	160	
	- off-time (s)	9,8	
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	utilization category (AC-3 or AC-4)	AC3	
	rated operational voltage Ue (V)	400V	
	rated operational current Ie (A) or power (kW)	85A	
	Conditions, make operations AC3/AC4 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 426 L2: 423 L3: 425	
	- test current I/Ie = (A)	L1: 1115 L2: 1114 L3: 1115	
	- power factor/time constant	L1: 0,32 L2: 0,32 L3: 0,31	
	- on-time (ms)	100	
	- off-time (s)	30	
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 67 L2: 68 L3: 67	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC3	
	rated operational voltage Ue (V)	400	
	rated operational current Ie (A) or power (kW)	85A	
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 425 L2: 424 L3: 426	
	- test current I/Ie = (A)	L1: 221 L2: 222 L3: 221	
	- power factor/time constant	L1: 0,32 L2: 0,33 L3: 0,33	
	- on-time (ms)	100	
	- off-time (s)	4	
	- number of make/break operations	6000	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		
	Measured oscillatory frequency (kHz)	L1: 49 L2: 48 L3: 48	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	
	rated operational voltage (V)	690	
	rated operational current I _e (A) or power (kW)	150A	
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 740 L2: 739 L3: 739	
	test current (A)	L1: 172 L2: 172 L3: 173	
	power factor/time constant	L1: 0,81 L2: 0,8 L3: 0,81	
	- on-time (ms)	160	
	- off-time (s)	4,8	
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r":		
	type of SCPD	Siemens NH2 gL / gG	
	ratings of SCPD, co-ordination type 1	250A / 500V	
	ratings of SCPD, co-ordination type 2	-	
	rated operational current Ie (A) AC-3	85A	
	prospective current "r" (kA)	5	
	test voltage (V)	L1: 421 L2: 421 L3: 423	
	r.m.s. test current (A)	L1: 5010 L2: 5070 L3: 5090	
	peak current (A)	L1: 7440 L2: 7920 L3: 6180	
	power factor	0,7	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dt _a (A ² s) / peak current I (A)	L1: 473 kA ² s / 6700A L2: 529 kA ² s / 6570 A L3: 549 kA ² s / 5700 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dt _a (A ² s) / peak current I (A)	L1: 474 kA ² s / 6335 A L2: 465 kA ² s / 6730 A L3: 558 kA ² s / 6890 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		
9.3.4.2.2	Test at the rated conditional short-circuit current "Iq" ≤ SCC "r"		N
	type of SCPD		
	ratings of SCPD, co-ordination type 1		
	ratings of SCPD, co-ordination type 2		
	rated operational current Ie (A) AC-3		
	prospective current "Iq" (kA)		
	test voltage (V)	L1: L2: L3:	
	r.m.s. test current (A)	L1: L2: L3:	
	peak current (A)	L1: L2: L3:	
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I²dta (A²s)	L1: L2: L3:	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)		P
	Overload current withstand capability of contactors:		P
	ambient temperature (°C)	25	
	rated operational current Ie (A) max. AC-3	85	
	test current (Ie) (A)	680	
	duration of test: 10 s	10s	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements			P
Temperature of object	Fig	Temp	Remark
Main Terminals Contactor (170A)	1	58	70
	3	59	70
	5	60	70
	4	59	70
	13	41	65
Auxiliary Terminals Contactor (16A)	14	42	65
	43	40	65
Auxiliary Terminal Overload Relay (4A)	95	40	65
	96	35	65
Coil:	240V	50Hz	70
	24V + 10%	DC	60



EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1: 266 L2: - L3: -	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- on-time (ms)	300	
	- operating cycles per minute	6	
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	
	rated operational voltage Ue (V)	240	
	rated operational current Ie (A) or power (kW)	12	
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	
	- power factor/time constant	L1: 0,31 L2: - L3: -	
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	
	- operating cycles per minute	15	
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		
	rated operational voltage Ue (V)		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict

EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD	25A / 500V	
	prospective current (kA)	1	
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	
	time interval between test (min. 3 min)		
	second making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	
	time interval between test (min. 3 min)		
	third making operation to closed switching elements: test I^2dt_a (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

TEST REPORT EN 60 947-4-1 Low-voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1: Electromechanical contactors and motor-starters	
Report reference No.	: 2.03.00356.1.0-K110/B&J
Tested by (+ signature).....	: Ing.J.Ainetter 
Approved by (+ signature)	: Ing.K.Farhofer 
Date of issue	: 02.02.2004
Testing laboratory	: Österreichische Forschungs- und Prüfzentrum Arsenal Ges.m.b.H
Address.....	: A – 1031 Vienna, Faradaygasse 3
Testing location.....	: as above
Applicant	: Benedict GmbH (Ω Benedikt & Jäger)
Address.....	: A – 1220 Vienna, Lieblgasse 7
Standard	: EN 60 947-4-1:2000-11
Test Report Form No.	: 69474 - 1A
Master TRF	: reference No. 69474-1A, dated 95-07
Copyright blank test report.....	: the bodies participating in the Committee of Certification Bodies (CCB) and/or the CENELEC Certification Agreement (CCA).
Test procedure	: CB-scheme
Procedure deviation	: N.A.
Non-standard test method	: N.A.
Type of test object	: Motor-Starter
Trademark	: Ω, Benedikt & Jäger
Model/type reference	: K110Axx + U85x
Manufacturer.....	: Ω Benedikt & Jäger
Rating	: AC1 170A 690V 50-60Hz AC3/AC4 110A 400V 50-60Hz AC15 12A 240V 50-60Hz

Copy of marking plate

Contactor K110A

1 L1

3 L2

5 L3



K110

IEC/EN60947-4-1 VDE0660

AC1 I_n 170A U_e 850V~
AC2, AC3

220 - 230V~	33kW
240V~	35kW
380 - 400V~	55kW
415 - 440V~	63kW
500V~	75kW
660 - 690V~	55kW

Made in Austria

WIRE 75°C Cu ONLY
TIGHTENING TORQUE 162 lb.-in.
3 AWG - 0 AWG SINGLE
SUITABLE FOR USE ON A CIRCUIT
CAPABLE OF DELIVERING NOT
MORE THAN 10000 RMS
SYMMETRICAL AMPERES.
600 VOLTS MAXIMUM
WHEN PROTECTED BY A
FUSE RATED 300 AMP.

LISTED IND. CONT. EQ. 93B2

	Motor load	
	3ph ac	1ph ac
115 v	-	10 hp
200 v	30 hp	20 hp
230 v	40 hp	20 hp
460 v	75 hp	-
575 v	100 hp	-
600v	125 amp	
Aux. cont. A600		

2 T1

4 T2

6 T3


Overload Relay U85 90

IEC/EN60947 VDE0660 750V~
Auslöseklasse / Trip class: 10A

entspr. Leitung **60-90A**
adequate to conductor

600VA
max. 4A

Made in
Austria



LISTED IND.

CONT. EQ. 93B3

600v ac

Fuse size
max. **300A**

Suitable for use on a circuit capable of delivering
not more than 10kA rms. sym. 600v max.

Numbers on dial are full load motor currents.
Tripping current is 125% of numbers on dial.

96 98


150v 95 97

600v 95 97


500va max. 4A



Photo:
Contactor K110



Overload Relay U85



Test item particulars:

- method of operation : Magnetic
- switching positions : ON-OFF
- number of poles.....Contactor: 3 Main 4 Aux
- kind of current..... : AC
- number of phases..... : 3
- rated frequency (Hz)..... : 50-60
- number of positions of main contacts..... : 2

Rated and limiting values, main circuit..... :

- rated operational voltage U_e (V) : 690
- rated insulation voltage U_i (V) : 690
- rated impulse withstand voltage U_{imp} (kV)..... : 8
- conventional free air thermal current I_{th} (A)..... : 170
- conventional enclosed thermal current I_{the} (A) : 170
- rated operational current I_e (A) : 170
- rated uninterrupted I_u (A) : 170
- utilization category..... : AC1, AC3

Short-circuit characteristic..... :

- rated prospective short-circuit current "r" (kA) : 5
- rated conditional short-circuit current I_q (kA) : 5

Rated and limiting values, auxiliary circuits..... : For Contactor

- rated operational voltage (V)..... : 240
- rated frequency (Hz)..... : 50-60
- number of circuits : Max. 4
- number and kind of contact elements : 2 NO and 2 NC

Co-ordination of short-circuit protective devices : Type "1"

- kind of protective device..... : Fuse

Possible test case verdicts:

- test case does not apply to the test object..... : N(A.)
- test object does meet the requirement..... : P(ass)
- test object does not meet the requirement..... : F(ail)

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

1) Based on the decision of the applicant, some of the tests of Test Sequences I and II may have been performed under more severe conditions than required in the standard. In case of, relevant values for equipment under test are stated in test report.

2) The test item is corresponding to the requirements of IEC 60947-4-1 Ed. 2.0 (2000-11) + A1 (2002-09).

Ordering key:**Contactor**

K110A x x x

 | | | >>>> : = : DC Supply (optional)
 | | >>>> : 0, 1, 2, 3, 4 : Number of NC auxiliary contacts
 | >>>> : 0, 1, 2, 3, 4 : Number of NO auxiliary contacts

Overload Relay

U85 x

 | >>>> : Setting range 60 – 90 / 80 – 120 A

Control Circuit Voltage:

6 – 550V 50Hz

6 – 600V 60Hz

12 – 250V DC

With Late Break Contact in series to coil.

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
6.2	MARKING:		
	Data shall be preferably marked on the equipment:		P
	c - number of this standard (IEC/EN60947-4-1)	IEC947-4-1	P
	k - IP code, in case of an enclosed equipment	-	N
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	d - rated operational voltages	690V	P
	e – utilization category and rated operational currents (or rated powers), at the rated operational voltages of the equipment	AC1 170A, 690V AC3 110A, 400V Contactor AC15 12A, 240V	P
	f - either the value of the rated frequency/ies, or the indication d.c. (or symbol)	50-60Hz	P
	g - rated duty with the indication of the class of intermittent duty, if any		N
	Associated values:		
	h - rated marking and breaking capacities (these indications may be replaced, where applicable, by the indication of the utilization category)	AC1, AC3, AC15	P
	Safety an installation:		
	i - rated insulation voltage	690V	P
	j - rated impulse withstand voltage	8 kV	P
	l – pollution degree	3	P
	m - rated conditional short-circuit current and type of co-ordination of contactor or starter and type, current rating and characteristics of the associated SCPD:		P
	m - rated conditional short-circuit current of the combination starter or the protected starter	5 kA Type '1' 250A fuse gL/gG	P
	n – switching overvoltages	≤ 8 kV	P
	Control circuits: Contactor		
	The following information concerning control circuits shall be placed either on the coil or on the equipment:		
	o - rated control circuit voltage (Uc), nature of current and rated frequency	6-550V 50Hz / 6-600V 60Hz 12-250V =	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	p - if necessary, nature of current, rated frequency and rated control supply voltages (Us)	Us = Uc	P
	Auxiliary circuits: Contactor		
	r - ratings of auxiliary circuits	AC15 12A, 240V	P
	Overload relays and releases:		
	s - characteristics according to 5.7	P	P

8.1	CONSTRUCTION: Overload relay		
8.1.1	Materials		P
	Resistance to abnormal heat and fire		P
	-parts retain current-carrying parts: 850 / 960°C	Housing (black) Cover (grey)	P
	- other: 650°C		N
8.1.2	Current-carrying parts and their connection		P
8.1.3	Clearances		P
	Uimp is given as:	8kV	P
	- max. value of rated operational voltage to earth :	600V	—
	- nominal voltage of supply system	400 / 690V	—
	- overvoltage category	IV	—
	- pollution degree	3	—
	- field-in or homogeneous	Inhomogeneous	—
	- minimum clearances (mm)	8	—
	- measured clearances (mm)	≥10	—
	Uimp is not given:		N
	- rated insulation voltage Ui (V)		—
	- Ie		—
	- minimum clearances L-L/L-A (mm)		—
	- measured clearances L-L/L-A (mm)		—
	Creepage distances		
	Uimp is given as:	8 kV	

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- material group or CTI	Min. III b	
	- minimum creepage distances (mm)	10	
	- measured creepage distances (mm)	≥ 12,5	
	Uimp is not given:		N
	- material column a or b		
	- minimum creepage distances (mm)		
	- measured creepage distances (mm)		
8.1.4	Actuator		N
8.1.4.1	Insulation		N
8.1.4.2	Direction		N
8.1.4.3	Mounting		N
8.1.5	Indication of contact position		N
8.1.5.1	Indication means		N
8.1.5.2	Indication by the actuator		N
8.1.6	Additional safety requirements for equipment with isolating function		N
8.1.7	Terminals		P
8.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals:	Contactor	
8.2.4.2	Mechanical strength of terminals		

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	maximum cross-sectional area of conductor (mm ²)	70	—
	diameter of thread (mm)	M 8	—
	torque (Nm)	3,5	—
	5 times on 2 separate clamping units		P
8.2.4.3	Testing for damage to and accidental loosening of conductor (flexion test)		
	conductor of the smallest cross-sectional area (mm ²)	10	—
	number of conductor of the smallest cross section	1	—
	diameter of bushing hole (mm)	9,5	—
	height between the equipment and the platen (mm)	279	—
	mass at the conductor(s) (kg)	2	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.2.4.4	Pull-out test		
	force (N)	90	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test		
	conductor of the largest cross-sectional area (mm ²)	70	—
	number of conductor of the largest cross-sectional	1	—
	diameter of bushing hole (mm)	19,1	—
	height between the equipment and the platen (mm)	368	—
	mass at the conductor(s) (kg)	14	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	285	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Flexion test	Contactor	
	conductor of the largest and smallest cross-sectional area (mm ²)	10 70	—
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional	1 1	—
	diameter of bushing hole (mm)	9,5 19,1	—
	height between the equipment and the platen (mm)	279 368	—
	mass at the conductor(s) (kg)	2 14	—
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
	Pull-out test		
	force (N)	90 285	—
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
8.1.7.2	Connecting capacity		P
	type of conductors	Semi Rigid Flexible	—
	minimum cross-sectional area of conductor (mm ²)	10 16	—
	maximum cross-sectional area of conductor (mm ²)	70 50	—
	number of conductors simultaneously connectable to the terminal	Acc. Manuf. Instr. 2 2	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.7.3	Connection		P
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
8.1.7.4	Terminal identification and marking		P
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals		P
	- Main circuit::	-	
	- Auxiliary circuit	95-96, 97-98, 13-14, 21- 22, 31-32, 43-44, A1, A2	
8.1.8	Additional requirements for equipment provided with a neutral pole		N
	marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
8.1.9	Provisions for protective earthing		N
8.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
8.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.1.9.3	Protective earth terminal marking and identification		N
8.1.10	Enclosure for equipment		N
8.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
8.1.10.2	Insulation		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
8.1.11	Degree of protection of enclosed equipment		N
	Degree of protection	IP	N
	Test for first characteristic		N
	Test for first numeral	1: 2: 3: 4: 5: 6:	
	Test for second characteristic		N
	Test for second numeral	1: 2: 3: 4: 5: 6: 7: 8:	

9.3.1.a	TEST SEQUENCE I		
9.3.3.3	Temperature rise	Type AC DC	P
	ambient temperature 10-40 °C	25	
	Contactor		N
	test enclosure W x H x D (mm x mm x mm)	350 x 175 x 145	
	material of enclosure	Metal	
	Main circuits, test conditions:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- conventional thermal current I _{th} (A)	170	—
	- conventional enclosed thermal current I _{the} (A) ..	170	—
	- cable/busbar cross-section (mm ²) / (mm)	70	—
	- temperature rise of main circuit terminals (K)	≤ 60	—
	Auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	16	—
	- cable cross-section (mm ²)	2,5	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 42	—
	Coils and electromagnets, test conditions:	AC DC	P
	- rated control supply voltage U _s (V)	240 24	—
	- Class of insulating material	F F	—
	- temperature rise of coil and electromagnets (K) :	≤ 70 ≤ 60	—
	Starter	Tested with setting range 80 – 120 A	
	test enclosure W x H x D (mm x mm x mm)	Open Type	—
	material of enclosure	None	—
	Main circuits, test conditions:		P
	- conventional thermal current I _{th} (A)	170	—
	- cable/busbar cross-section (mm ²) / (mm)	70 mm ²	—
	- temperature rise of main circuit terminals (K)	≤ 60 Temp. Rise on Contactor terminals only. Worst Case AC1 170A instead of AC3 110A	—
	Overload relay, auxiliary circuit, test conditions:		P
	- rated operation current I _e (A)	4	—
	- cable cross-section (mm ²)	1	—
	- temperature rise of auxiliary circuit terminals (K)	≤ 40	—
9.3.3.2	Operating limits		
9.3.3.2.1	Power-operated equipment:	AC DC	P
	rated control supply voltage U _s (V)	240 24	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	frequency (Hz)	50 DC	—
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us	73 65	P
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c.	57 25	P
9.3.3.2.2	Relays and releases Setting Range 80 – 120 A		P
	Conditions for thermal and time-delay magnetic overload relays only:		p
	type of time-delay overload relay	Thermal, Temp. Compensated with current Transformer	—
	trip class	20	—
	current settingI _{set} :	80 A 120 A	—
	ambient temperature (°C)	24	—
	test enclosure W x H x D (mm x mm x mm)	None	—
	cable/busbar cross-section (mm ²) / (mm)		—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	84 A 126 A No tripping No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current min:sec :	96 A 144 A 3:20 2:35	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	N	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time min:sec :	120 A 180 A 0:20 0:23	—

EN 60 947-4-1				
Clause	Requirement – Test	Result - Remark		Verdict
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20$, starting from the cold state; test current; tripping time T_p (s)	576 A	864 A	—
		10	14	—
	Ambient temperature: - 5 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	84 A	126 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	96 A	144 A	—
	min:sec :	28:00	3:45	—
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current	N		—
	min:sec :			—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time	120	180 A	—
	min:sec :	1:15	1:35	—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20s$ starting from the cold state; test current; tripping time T_p (s)	576 A	864 A	—
		13	16	—
	Ambient temperature: + 40 °C			—
	at A (1,05) times of current setting, tripping shall not occur in less than 2 h starting from the cold state; test current	84 A	126 A	—
		No tripping	No tripping	—
	When the current is subsequently raised to B (1,2) times the current setting, tripping shall occur in less than 2 h; test current	96 A	144 A	—
	min:sec :	2:40	1:45	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	for class 10A overload relays energized at C (1,5) times the current, tripping shall occur in less than 2 min, starting from thermal equilibrium at the current setting; test current min:sec :	N	—
	for class 10, 20 or 30 overload relays energized at C times the current, tripping shall occur in less than 2, 8 or 12 min, starting from thermal equilibrium at the current setting; class; test current; tripping time min:sec :	120 A 180 A 0:17 0:55	—
	at D (7,2) times the current setting, tripping shall occur within the tripping time (s) $6 < T_p \leq 20$ starting from the cold state; test current; tripping time T_p (s)	576 A 864 A 12 15	—
	Limits of operation of three-pole thermal overload relays energized on two poles:		P
	ambient temperature (°C)	25	—
	the relay energized on three poles, at A (1 / 0,9) times the current setting, tripping shall not occur in less than 2 h, starting from the cold state	80 A / 72 A 120 A / 108 A No tripping No tripping	—
	when the value of the current flowing in two poles is increased to B (1,15) times the current setting and the third pole deenergized, tripping shall occur in less than 2 h min:sec :	92 A / 0 A 138 A / 0 A 1:45 1:15	—
9.3.3.4	Test of dielectric properties, impulse withstand voltage (U_{imp} indicated):		P
	- verification by measurement of clearances instead of testing		N
	- rated impulse withstand voltage (V)	8000	—
	- test U_{imp} main circuits (kV)	9,8 / 7	P
	- test U_{imp} auxiliary circuits (kV)	9,8 / 7	P
	Test of dielectric properties, dielectric withstand voltage (U_{imp} not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- control and auxiliary circuits, test voltage for 1 min (V)		N

9.3.3.5	TEST SEQUENCE II		
	Making and breaking capacity		
	utilization category	AC1	
	rated operational voltage U_e (V)	690	
	rated operational current I_e (A) or power (kW)	170A	
	Conditions, make/break operations AC-1 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 740 L2: 739 L3: 739	
	- test current $I/I_e = 1,5$ (A)	L1: 262 L2: 262 L3: 263	
	- power factor/time constant	L1: 0,8 L2: 0,79 L3: 0,8	
	- on-time (ms)	160	
	- off-time (s)	9,8	
	- number of make/break operations	50	P
	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P
	Operational performance capability:		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	utilization category (AC-3 or AC-4)	AC3	—
	rated operational voltage Ue (V)	400V	—
	rated operational current Ie (A) or power (kW)	110A	—
	Conditions, make operations AC3/AC4 only:		P
	- test voltage U/Ue = 1,05 (V)	L1: 426 L2: 423 L3: 425	—
	- test current I/Ie = (A)	L1: 1115 L2: 1114 L3: 1115	—
	- power factor/time constant	L1: 0,32 L2: 0,32 L3: 0,31	—
	- on-time (ms)	100	—
	- off-time (s)	30	—
	- number of make operations	50	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 67 L2: 68 L3: 67	
	Factor y	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
	Operational performance capability:		
	utilization category	AC3	—
	rated operational voltage U_e (V)	400	—
	rated operational current I_e (A) or power (kW)	110A	—
	Conditions, make/break operations AC3 / AC4 only:		P
	- test voltage $U/U_e = 1,05$ (V)	L1: 425 L2: 424 L3: 426	—
	- test current $I/I_e =$ (A)	L1: 221 L2: 222 L3: 221	—
	- power factor/time constant	L1: 0,32 L2: 0,33 L3: 0,33	—
	- on-time (ms)	100	—
	- off-time (s)	4	—
	- number of make/break operations	6000	P
	Characteristic of transient recovery voltage for AC-3 and AC-4 only:		P
	oscillatory frequency (kHz)		—
	Measured oscillatory frequency (kHz)	L1: 49 L2: 48 L3: 48	
	Factor γ	L1: 1,1 L2: 1,1 L3: 1,1	
	Behaviour and condition during and after the test:		P
	- no permanent arcing	P	P
	- no flash-over between poles	P	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	- no blowing of the fusible element in the earth circuit	P	P
	- no welding of the contacts	P	P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control	P	P
8.3.3.6	Operational performance capability:		
	utilization category	AC1	—
	rated operational voltage (V)	690	—
	rated operational current I _e (A) or power (kW)	170A	—
	Test conditions for make/break operations AC-1 only:		P
	test voltage (V)	L1: 740 L2: 739 L3: 739	—
	test current (A)	L1: 172 L2: 172 L3: 173	—
	power factor/time constant	L1: 0,81 L2: 0,8 L3: 0,81	—
	- on-time (ms)	160	—
	- off-time (s)	4,8	—
	- number of operating cycles	6000	P
8.3.3.6.6	Behaviour and condition during and after the test:		P
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	- the contacts shall operate when the contactor or starter is switched by the applicable method of control		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Dielectric verification:		P
	test voltage (2 Ue + 1000 V) for 1 min (V)	2380	

9.3.4	TEST SEQUENCE III		
	Performance under short-circuit conditions		
9.3.4.2.1	Test at de prospective current "r":		
	type of SCPD	Siemens NH2 gL / gG	
	ratings of SCPD, co-ordination type 1	250A / 500V	
	ratings of SCPD, co-ordination type 2	-	
	rated operational current Ie (A) AC-3	85A	
	prospective current "r" (kA)	5	
	test voltage (V)	L1: 421 L2: 421 L3: 423	
	r.m.s. test current (A)	L1: 5010 L2: 5070 L3: 5090	
	peak current (A)	L1: 7440 L2: 7920 L3: 6180	
	power factor	0,7	
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dta (A ² s) / peak current I (A)	L1: 473 kA ² s / 6700A L2: 529 kA ² s / 6570 A L3: 549 kA ² s / 5700 A	
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit I ² dta (A ² s) / peak current I (A)	L1: 474 kA ² s / 6335 A L2: 465 kA ² s / 6730 A L3: 558 kA ² s / 6890 A	
	Behaviour of the equipment during the test		P
	Both types of co-ordination (all devices):		P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		P
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		P
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		P
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		P
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		P
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation	P	P

EN 60 947-4-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Type 1 co-ordination (combination and protected starters only):		P
	I - dielectric verification test voltage (2 Ue) for 1 min (V)	1380	—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—
9.3.4.2.2	Test at the rated conditional short-circuit current " $I_q \leq SCC_r$ "		N
	type of SCPD		—
	ratings of SCPD, co-ordination type 1		—
	ratings of SCPD, co-ordination type 2		—
	rated operational current Ie (A) AC-3		—
	prospective current "Iq" (kA)		—
	test voltage (V)	L1: L2: L3:	—
	r.m.s. test current (A)	L1: L2: L3:	—
	peak current (A)	L1: L2: L3:	—
	power factor		
	1. one breaking operation of SCPD with all the switching devices closed prior to the test I ² dt _a (A ² s)	L1: L2: L3:	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	2. one breaking operation of SCPD by closing the contactor or starter on to the short-circuit	L1: L2: L3:	
	3. one breaking operation of SCPD by closing the switching device on to the short-circuit	L1: L2: L3:	
	Behaviour of the equipment during the test		N
	Both types of co-ordination (all devices):		N
	A - the fault current has been successfully interrupted by the SCPD or the combination starter and the fuse or fusible element, or solid connection between the enclosure and supply shall not have melted		N
	B - the door or cover of the enclosure has not been blown open and it is possible to open the door or cover		N
	C - there is no damage to the conductors or terminals and the conductors have not been separated from the terminals		N
	D - there is no cracking or breaking of an insulating base to the extent that the integrity of mounting of a live part is impaired		N
	Both types of co-ordination (combination starters and protected starters only):		N
	E - the circuit breaker or the switch is capable of being opened manually by its operating means		N
	F - neither end of the SCPD is completely separated from its mounting means to an exposed conductive part		N
	G - if a circuit breaker with rated ultimate short-circuit breaking capacity less than the rated conditional short-circuit current assigned to the combination or protected starter is employed, the circuit breaker shall be tested to trip:		N

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	1) circuit breaker with instantaneous trip relays or releases, at 120% of the trip current		N
	2) circuit breaker with overload relays or releases, at 250% of the rated current of the circuit breaker		N
	Type 1 co-ordination (all devices):		N
	H - there has been no discharge of parts beyond the enclosure. The starter may be inoperative after each operation		N
	Type 1 co-ordination (combination and protected starters only):		N
	I - dielectric verification test voltage (2 Ue) for 1 min (V)		—
	Type 2 co-ordination (all devices):		N
	J - no damage to the overload relay or other parts has occurred, except that welding of contactor or starter contacts is permitted, if they are easily separated without significant deformation		N
	K - the tripping of the overload relay shall be conform to the published tripping characteristics, before and after the test		N
	L - dielectric verification test voltage (2 Ue) for 1 min (V)		—

9.3.5	TEST SEQUENCE IV: (APPLICABLE FOR CONTACTORS ONLY)	P
	Overload current withstand capability of contactors:	P
	ambient temperature (°C): 25	—
	rated operational current Ie (A) max. AC-3: 110	—
	test current (Ie) (A): 880	—
	duration of test: 10 s: 10s	—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
	After the test, the contactor shall be substantially in the same condition as before the test (visual inspection)	P	P

TABLE: temperature rise measurements			P
temperature rise dT of part:	No.	dT (K)	Required dT (K)
Main Terminals Contactor (170A)	1	58	70
	3	59	70
	5	60	70
	4	59	70
Auxiliary Terminals Contactor (16A)	13	41	65
	14	42	65
	43	40	65
Auxiliary Terminal Overload Relay (4A)	95	40	65
	96	35	65
Coil:	240V 50Hz	70	135
	24V + 10% DC	60	135

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions:		P
	utilization category	AC15	—
	rated operational voltage Ue (V)	240	—
	rated operational current Ie (A) or power (kW)	12	—
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1: 266 L2: - L3: -	—
	- power factor/time constant	L1: 0,31 L2: - L3: -	—
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	—
	- break operations: test current I/Ie (A)	L1: 123 L2: - L3: -	—
	- on-time (ms)	300	—
	- operating cycles per minute	6	—
	- number of operating cycles	10	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.3.5	TEST SEQUENCE III		
8.3.3.5.2	Making and breaking capacities of switching elements under normal conditions		P
	utilization category	AC15	—
	rated operational voltage Ue (V)	240	—
	rated operational current Ie (A) or power (kW)	12	—
	Conditions, make/break operations:		P
	- test voltage U/Ue = 1,1 (V) * 50 operation at 266V ** 6000 operations at 242V	L1: 266* / 242 ** L2: L3:	—
	- power factor/time constant	L1: 0,31 L2: - L3: -	—
	- make operations: test current I/Ie (A)	L1: 123 L2: - L3: -	—
	- break operations: test current I/Ie (A)	L1: 13 L2: - L3:	—
	- on-time (ms) *50 oper. / **6000 oper.	160 * / 300**	—
	- operating cycles per minute	15	—
	- number of operating cycles	6050	P
	Behaviour and condition during and after the test:		P
	- no electrical or mechanical failures		P
	- no contact welding or prolonged arcing		P
	- no blowing of the fusible element in the earth circuit		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P
	utilization category		—
	rated operational voltage Ue (V)		—

EN 60 947-4-1			
Clause	Requirement – Test	Result - Remark	Verdict
EN 60 947-5-1			
8.3.4	TEST SEQUENCE IV		
	Performance under conditional short-circuit current		P
	type of SCPD	Siemens Diazed gL / gG	
	ratings of SCPD	25A / 500V	
	prospective current (kA)	1	
	test voltage (V) $U/U_e = 1,1$ (V)	L1: 277 L2: 275 L3: 276	
	r.m.s. test current (A)	L1: 1010 L2: 1050 L3: 1020	
	power factor (max. 0,7)	0,7	
	first making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1650 A ² s / 770A L2: 2880 A ² s / 830 A L3: 2850 A ² s / 1090 A	
	time interval between test (min. 3 min)		
	second making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 1430 A ² s / 700 A L2: 2900 A ² s / 830 A L3: 2860 A ² s / 1080 A	
	time interval between test (min. 3 min)		
	third making operation to closed switching elements: test I^2dta (A ² s) / I_D (A)	L1: 2910 A ² s / 1030 A L2: 2540 A ² s / 975 A L3: 830 A ² s / 545 A	
	Behaviour of the equipment during the test:		P
	switching elements open by the normal actuating system		P
	Dielectric verification:		P
	dielectric test voltage (V)	2000	P