

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contact Block

Name and address of the applicant

Benedict GmbH  
Liebgasse 7,  
1220 Wien, Austria

Name and address of the manufacturer

Benedict GmbH  
Liebgasse 7,  
1220 Wien, Austria

Name and address of the factory

Benedict GmbH  
Liebgasse 7,  
1220 Wien, Austria

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

HNxx: AC-1 690V/10A, AC-15 230V/3A, 400V/2A, 690V/0,5A;  
HAxx: AC-1 690V/25A, AC-15 230V/6A, 400V/3A, 500V/2A, 690V/1A;  
HKxx: AC-1 690V/10A, AC-15 230-240V/3A, 380-415V/2A;  
HBxx (LHxx): AC-1 690V/10A, AC-15 230V/3A, 400V/2A;  
50-60 Hz, see page 11 of test report

Trademark (if any)

 BENEDICT,  Benedikt & Jäger

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

HNxx, HAxx, HKxx, HBxx (LHxx)  
see page 7 to 9 of test report

Additional information (if necessary may also be reported on page 2)

The Auxiliary Contact Blocks for use with contactors K3 series

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-07882/Aux. Contacts/HN,HA,HK,HB(LH)/CB


This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik  
Testing & Certification  
Kahlenberger Str. 2A, 1190 Wien, Austria



Date: 2018-08-07



Digitally signed by W. Martin  
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin