



Ref. Certif. No.

AT 4198/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Contactors

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Additional Information on page 2

K3-24K...: 400 V, 50/60 Hz, 20 kVAr and 690 V, 50/60 Hz, 33 kVAr;
K3-32K...: 400 V, 50/60 Hz, 25 kVAr and 690 V, 50/60 Hz, 41 kVAr;
Utilization category AC-6b

Ω

CTF Stage 2

K3-24K..., K3-32K...,
see type spectrum on page 20 of test report CTI-CB 1066-1

In addition to CB/AT 4198, dated 2019-07-08.
Additional types for capacitive load.

Additional Information on page 2

IEC 60947-4-1:2018

CTI-CB 1066-1

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik
Testing and Certification
Kahlenberger Str. 2A, 1190 Wien, Austria



Date: 2020-12-18

W. Martin

Digitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin