

AT 4201

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Contactors

Name and address of the applicant

Benedict GmbH Lieblgasse 7, 1220 Wien, Austria

Name and address of the manufacturer

Benedict GmbH Lieblgasse 7, 1220 Wien, Austria

Name and address of the factory

Benedict GmbH Lieblgasse 7, 1220 Wien, Austria

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue = 440 V, 50 Hz; le = 20 A: R20-..., 25 A: R25-...; 2p; AC1

. .

Trademark (if any)

Ω

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

R20-..., R25-..., see type spectrum on page 13 of test report CTI-CB 992-1

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 992-1

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

Testing and Certification Kahlenberger Str. 2A, 1190 Wien, Austria

Digitally signed by W. Martin Email=w.martin@ove.at

ature: Dipl.-Ing. W. Martin

Date: 2019-07-08