

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Name and address of the manufacturer

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Name and address of the factory

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue = AC 690 V; Ie = 50 A; AC 21A;  
Ue = AC 440 V; Ie = 45 A; AC 23A;  
see also page 5 of test report.

Trademark (if any)

 $\Omega$ 

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

N33F...,  
see type key on page 7 of test report.

Additional information (if necessary may also be reported on page 2)

--

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007	IEC 60947-3:2008
IEC 60947-1:2007/AMD1:2010	IEC 60947-3:2008/AMD1:2012
IEC 60947-1:2007/AMD2:2014	IEC 60947-3:2008/AMD2:2015


As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1013-1

This CB Test Certificate is issued by the National Certification Body

Österreichischer Verband für Elektrotechnik  
Testing and Certification  
Kahlenberger Str. 2A, 1190 Wien, Austria

Date: 2019-10-28

Digitally signed by W. Martin  
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin