

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electromechanical contactors

Name and address of the applicant

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Name and address of the manufacturer

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Name and address of the factory

Benedict GmbH
Lieblgasse 7,
1220 Wien, Austria

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

U_e = AC 415 V, 50-60 Hz;
I_e = 25 A (K3-10NR..., K3-14NR...) or 32 A (K3-18NR..., K3-22NR...);
Utilization category: AC-1; see also pages 9 to 11 of test report

Trademark / Brand (if any)

Ω

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

K3-10NR..., K3-14NR..., K3-18NR..., K3-22NR...

Additional information (if necessary may also be reported on page 2)

--

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018


As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-18756/K3-10NR,14NR,18NR,22NR/CB

This CB Test Certificate is issued by the National Certification Body

Österreichischer Verband für Elektrotechnik
Testing and Certification
Kahlenberger Str. 2A, 1190 Wien, Austria

Date: 2020-05-12

Digitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin