



Ref. Certif. No.

**AT 4484**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Contactors

Name and address of the applicant

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Name and address of the manufacturer

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Name and address of the factory

Benedict GmbH  
Lieblgasse 7,  
1220 Wien, Austria

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Ue=690 V, 50-60 Hz, Utilization category AC-6b,  
K3-90A00.: 120kVAr,  
K3-115A00.: 148kVAr;

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

K3-90K00.,K3-115K00., see type spectrum on page 16 of testreport  
CTI-CB 1065-2.

Additional information (if necessary may also be reported on page 2)

--

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1065-2

This CB Test Certificate is issued by the National Certification Body



**Österreichischer Verband für Elektrotechnik**  
Testing and Certification  
Kahlenberger Str. 2A, 1190 Wien, Austria



Date: 2020-11-18

*W. Martin*

Digitally signed by W. Martin  
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin